



CITY OF KYLE

520 E. RR 150
Office (512) 262-3024

Kyle, Texas 78640
Fax (512) 262-3403

ADDENDUM NO. 1

Request for Qualifications for Procurement of Professional Engineering Services for Wastewater Treatment Plant Expansion Phase 2 “K22-23.2”

December 21, 2022

1.0 Addenda Purpose

The purpose of this addendum is to modify/clarify sections of the issued RFQ or answer questions received from prospective responders.

2.0 Clarifications and Answers

NONE

3.0 Emailed Questions and Answers

Q1: We are looking at this RFQ and wondering if you will be contracting for geotechnical engineering services separately, or will geotechnical be included in this work scope?

Geotechnical work will be included in the scope of work for the design of the plant expansion.

Q2. After reviewing the RFQ mentioned above, we would like more information regarding the number of projects that the City wishes to see. Item 3(b) asks for “examples of at least three (3) similar projects ... by the principal and subconsultants” so is that 3 total for our proposal or 3 for the prime and 3 for each subconsultant? Thank you in advance for your clarification.

At least three (3) total projects should be included in the proposal. It does not have to be 3 each for the prime and subconsultants.

4.0 Pre-Submission Meeting Questions and Answers

Q1: What is the end use for the reclaim water, and is the delivery of the reclaim water apart of this scope?

The end use for the reclaim water will be to provide Type 1 reclaim water for use within the City of Kyle. It is currently not anticipated that reclaim water delivery be included in this scope.

Q2: Is there already a pre-constructed location for the installation of the new disc filters on-site?

There is not a pre-constructed location for the disc filters. This new structure will be included in the scope of work for the expansion.

Q3: Is there a construction cost estimate for the project?

No, there is not a cost estimate for the project.

Q4: Will a new UV Channel be required for the project?

We anticipate that an additional UV Channel will be required for the plant expansion.

Q5: Will Odor Control be needed for the project?

Currently there are no plans to include odor control in the scope of the project. An evaluation may need to occur if the need arises.



Leon Barba, P.E.
City Engineer