Jon Niermann, *Chairman*Emily Lindley, *Commissioner*Bobby Janecka, *Commissioner*Toby Baker, *Executive Director* 



### TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

Ms. Yvonne Gil-Vallejo, Project Manager City of Kyle 100 West Center Street Kyle, Texas 78640

Re: City of Kyle - TPDES Permit No. WQ0011041002, EPA ID No. TX0119466 (CN600334510; RN102182680)

Dear Ms. Gil-Vallejo:

Enclosed for your review and comment is a copy of a draft permit, Fact Sheet and Executive Director's Preliminary Decision for the above-referenced operation. This draft permit is subject to further staff review and modification; however, we believe it generally includes the terms and conditions that are appropriate to your discharge. Please read the entire draft carefully as there may be changes from the existing permit and note the following:

- 1. The applicant has applied for a major amendment to TPDES No. WQ0011041002 to authorize an increase in the discharge of treated domestic wastewater from an annual average flow limit not to exceed 4.5 MGD to an annual average flow limit not to exceed 12.0 MGD and the addition of an Interim II phase at an annual average flow not to exceed 9.0 MGD.
- 2. The draft permit will be issued to expire **three years from the date of issuance**. Due to two chronic failures by each test species occurring during the term of the existing permit, the permit will be issued for a three-year term, based on recommendations from the WQ Standards Implementation Team.
- 3. The Standard Permit Conditions, Sludge Provisions, Other Requirements, and Biomonitoring sections of the draft permit have been updated.
- 4. For Publicly Owned Treatment Works (POTWs), effective December 21, 2025, the permittee must submit the written report for unauthorized discharges and unanticipated bypasses that exceed any effluent limit in the permit using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver.
- 5. Effective December 21, 2025, the permittee must submit the annual sludge report using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. The Reporting Requirements of the Sludge Provisions have also been updated.

- 6. Certain accidental discharges or spills of treated or untreated wastewater from wastewater treatment facilities or collection systems owned or operated by a local government may be reported on a monthly basis in accordance with 30 TAC § 305.132.
- 7. Total Phosphorus limits of 0.5 mg/L have been placed in the permit in the Interim II and Final phases, based on recommendations by the WQ Standards Implementation Team.
- 8. The Interim I & II and Final phases have been placed in the permit to transition the annual average flow limits from 4.5 MGD to 12.0 MGD.
- 9. The draft permit includes all updates based on the 30 TAC § 312 rule change effective April 23, 2020.
- 10. If you do not have any comments on the draft permit, please inform me in writing and fax it to my attention at 512-239-4430 or e-mail Sonia.bhuiya@tceq.texas.gov indicating that you do not have any comments. If your response is received after the two-week official comment period deadline, the file will be forwarded to the Office of the Chief Clerk for processing.

Also enclosed for your review and comment is a copy of the draft second notice, the Notice of Application and Preliminary Decision (NAPD), that was prepared for your application. Please review this notice and provide comments if there are any inaccuracies or any information that is not consistent with your application. Please do not publish the notice at this time; after the draft permit is filed with the Office of the Chief Clerk, you will receive instructions for publishing this notice in a newspaper from the Office of the Chief Clerk. Please note that these instructions will not be mailed if the Office of the Chief Clerk has not received the requested proof that the first notice (Notice of Receipt and Intent to Obtain a Permit) has been published. This could cause delays in the processing of your application and the final issuance of the draft permit. When the NAPD notice is received, please publish promptly and submit proof of publication (affidavit and tearsheet) to the Office of the Chief Clerk. Failure to publish notice and submit proof of publication in a timely manner may result in returning of the application and loss of authorization to operate.

It is your responsibility to submit your comments on the draft permit prior to the deadline that is indicated in the email. Comments can be sent to Sonia.Bhuiya@tceq.texas.gov in place of or in addition to a hard copy.

Ms. Yvonne Gil-Vallejo, Project Manager Page 3

If you have any comments or questions, please contact me at (512) 239-1205, or if by correspondence, include MC 148 in the letterhead address following my name.

Sincerely,

## Sonia Bhuiya

Sonia Bhuiya, Permit Coordinator Municipal Permits Team Wastewater Permitting Section (MC 148) Water Quality Division Texas Commission on Environmental Quality

SB/SW

**Enclosures** 

# **Texas Commission on Environmental Quality**



#### NOTICE OF APPLICATION AND PRELIMINARY DECISION FOR TPDES PERMIT FOR MUNICIPAL WASTEWATER MAJOR AMENDMENT

#### **PERMIT NO. WQ0011041002**

APPLICATION AND PRELIMINARY DECISION. City of Kyle, 100 West Center Street, Kyle, Texas 78640, has applied to the Texas Commission on Environmental Quality (TCEQ) for a major amendment to Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0011041002 to authorize an increase in the discharge of treated domestic wastewater from an annual average flow limit not to exceed 4,500,000 gallons per day to an annual average flow limit not to exceed 12,000,000 gallons per day and the addition of an Interim II phase at an annual average flow not to exceed 9,000,000 gallons per day. TCEQ received this application on March 11, 2022.

The facility is located at 941 New Bridge Drive, in Hays County, Texas 78640. The treated effluent is discharged directly to Plum Creek in Segment No. 1810 of the Guadalupe River Basin. The designated uses for Segment No. 1810 are primary contact recreation, aquifer protection, and high aquatic life use. In accordance with 30 Texas Administrative Code § 307.5 and the TCEQ implementation procedures (June 2010) for the Texas Surface Water Quality Standards, an antidegradation review of the receiving waters was performed. A Tier 1 antidegradation review has preliminarily determined that existing water quality uses will not be impaired by this permit action. Numerical and narrative criteria to protect existing uses will be maintained. A Tier 2 review has preliminarily determined that no significant degradation of water quality is expected in Plum Creek, which has been identified as having high aquatic life use. Existing uses will be maintained and protected. The preliminary determination can be reexamined and may be modified if new information is received.

This link to an electronic map of the site or facility's general location is provided as a public courtesy and is not part of the application or notice. For the exact location, refer to the application.

https://tceq.maps.arcgis.com/apps/webappviewer/index.html?id=db5bac44afbc468bbddd360f8168250f&marker=-97.835277%2C29.967777&level=12

The TCEQ Executive Director has completed the technical review of the application and prepared a draft permit. The draft permit, if approved, would establish the conditions under which the facility must operate. The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The permit application, Executive Director's preliminary decision, and draft permit are available for viewing and copying at Kyle Public Library, 550 Scott Street, Kyle, Texas.

# DRAFT NOTICE, DO NOT PUBLISH UNTIL YOU RECEIVE THE OFFICIAL VERSION AND INSTRUCTIONS FROM TCEQ'S OFFICE OF THE CHIEF CLERK.

**PUBLIC COMMENT / PUBLIC MEETING. You may submit public comments or request a public meeting about this application.** The purpose of a public meeting is to provide the opportunity to submit comments or to ask questions about the application. TCEQ holds a public meeting if the Executive Director determines that there is a significant degree of public interest in the application or if requested by a local legislator. A public meeting is not a contested case hearing.

OPPORTUNITY FOR A CONTESTED CASE HEARING. After the deadline for submitting public comments, the Executive Director will consider all timely comments and prepare a response to all relevant and material, or significant public comments. Unless the application is directly referred for a contested case hearing, the response to comments will be mailed to everyone who submitted public comments and to those persons who are on the mailing list for this application. If comments are received, the mailing will also provide instructions for requesting a contested case hearing or reconsideration of the Executive Director's decision. A contested case hearing is a legal proceeding similar to a civil trial in a state district court.

TO REQUEST A CONTESTED CASE HEARING, YOU MUST INCLUDE THE FOLLOWING ITEMS IN YOUR REQUEST: your name, address, phone number; applicant's name and proposed permit number; the location and distance of your property/activities relative to the proposed facility; a specific description of how you would be adversely affected by the facility in a way not common to the general public; a list of all disputed issues of fact that you submit during the comment period; and the statement "[I/we] request a contested case hearing." If the request for contested case hearing is filed on behalf of a group or association, the request must designate the group's representative for receiving future correspondence; identify by name and physical address an individual member of the group who would be adversely affected by the proposed facility or activity; provide the information discussed above regarding the affected member's location and distance from the facility or activity; explain how and why the member would be affected; and explain how the interests the group seeks to protect are relevant to the group's purpose.

Following the close of all applicable comment and request periods, the Executive Director will forward the application and any requests for reconsideration or for a contested case hearing to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

The Commission may only grant a request for a contested case hearing on issues the requestor submitted in their timely comments that were not subsequently withdrawn. If a hearing is granted, the subject of a hearing will be limited to disputed issues of fact or mixed questions of fact and law relating to relevant and material water quality concerns submitted during the comment period. TCEQ may act on an application to renew a permit for discharge of wastewater without providing an opportunity for a contested case hearing if certain criteria are met.

**EXECUTIVE DIRECTOR ACTION.** The Executive Director may issue final approval of the application unless a timely contested case hearing request or request for reconsideration is filed. If a timely hearing request or request for reconsideration is filed, the Executive Director will not issue final approval of the permit and will forward the application and request to the TCEQ Commissioners for their consideration at a scheduled Commission meeting.

# DRAFT NOTICE, DO NOT PUBLISH UNTIL YOU RECEIVE THE OFFICIAL VERSION AND INSTRUCTIONS FROM TCEO'S OFFICE OF THE CHIEF CLERK.

**MAILING LIST.** If you submit public comments, a request for a contested case hearing or a reconsideration of the Executive Director's decision, you will be added to the mailing list for this specific application to receive future public notices mailed by the Office of the Chief Clerk. In addition, you may request to be placed on: (1) the permanent mailing list for a specific applicant name and permit number; and/or (2) the mailing list for a specific county. If you wish to be placed on the permanent and/or the county mailing list, clearly specify which list(s) and send your request to TCEQ Office of the Chief Clerk at the address below.

All written public comments and public meeting requests must be submitted to the Office of the Chief Clerk, MC 105, Texas Commission on Environmental Quality, P.O. Box 13087, Austin, TX 78711-3087 or electronically at www.tceq.texas.gov/goto/comment within 30 days from the date of newspaper publication of this notice.

**INFORMATION AVAILABLE ONLINE.** For details about the status of the application, visit the Commissioners' Integrated Database at www.tceq.texas.gov/goto/cid. Search the database using the permit number for this application, which is provided at the top of this notice.

AGENCY CONTACTS AND INFORMATION. Public comments and requests must be submitted either electronically at www.tceq.texas.gov/goto/comment, or in writing to the Texas Commission on Environmental Quality, Office of the Chief Clerk, MC 105, P.O. Box 13087, Austin, Texas 78711-3087. Any personal information you submit to the TCEQ will become part of the agency's record; this includes email addresses. For more information about this permit application or the permitting process, please call the TCEQ Public Education Program, Toll Free, at 1-800-687-4040 or visit their website at www.tceq.texas.gov/goto/pep. Si desea información en Español, puede llamar al 1-800-687-4040.

Further information may also be obtained from City of Kyle at the address stated above or by calling Mr. Timothy Samford, Division Manager of Treatment Operations, at 512-262-3024.

| Issuance Date |  |
|---------------|--|
|               |  |

#### FACT SHEET AND EXECUTIVE DIRECTOR'S PRELIMINARY DECISION

For draft Texas Pollutant Discharge Elimination System (TPDES) Permit No. WQ0011041002, EPA I.D. No. TX0119466, to discharge to water in the state.

Issuing Office: Texas Commission on Environmental Quality

P.O. Box 13087

Austin, Texas 78711-3087

Applicant: City of Kyle

100 West Center Street Kyle, Texas 78640

Prepared By: Sonia Bhuiya

**Municipal Permits Team** 

Wastewater Permitting Section (MC 148)

Water Quality Division

(512) 239-1205

Date: July 11, 2022

Permit Action: Major Amendment with Renewal

#### 1. EXECUTIVE DIRECTOR RECOMMENDATION

The Executive Director has made a preliminary decision that this permit, if issued, meets all statutory and regulatory requirements. The draft permit includes an expiration date of **five years from the date of issuance**.

#### 2. APPLICANT ACTIVITY

The applicant has applied to the Texas Commission on Environmental Quality (TCEQ) for an amendment of the existing permit to authorize an increase in the discharge of treated domestic wastewater from an annual average flow limit not to exceed 4.5 million gallons per day (MGD) to an annual average flow limit not to exceed 12.0 MGD; The existing wastewater treatment facility serves and the addition of an Interim II phase at an annual average flow not to exceed 9.0 MGD.

#### Outfall Location:

| Outfall Number | Latitude    | Longitude   |  |
|----------------|-------------|-------------|--|
| 001            | 29.968166 N | 97.833019 W |  |

The treated effluent is discharged directly to Plum Creek in Segment No. 1810 of the Guadalupe River Basin. o The designated uses for Segment No. 1810 are primary contact recreation, aquifer protection, and high aquatic life use.

#### 4. TREATMENT PROCESS DESCRIPTION AND SEWAGE SLUDGE DISPOSAL

The City of Kyle Wastewater Treatment Facility is an activated sludge process plant operated in the complete mix mode with nitrification. Treatment units in the Interim I phase include two fine screens, four lift stations, four aeration basins, four final

clarifiers, two post aeration basins, four aerobic sludge digestions and two ultravioletlight disinfection system. Treatment units in the Interim II phase will include four fine screens, six lift station, ten aeration basins, nine final clarifiers, four post aeration basins, four aerobic sludge digestions and three ultra-violetlight disinfection system. Treatment units in the Final phase will include six fine screens, twelve aeration basins, six lift station, twelve final clarifiers, four tertiary flters, ten post aeration basins, six aerobic sludge digestions and four ultra-violetlight disinfection system. The facility is operating in the interim I phase.

The draft permit also authorizes the disposal of sludge at a TCEQ-authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge.

#### 5. INDUSTRIAL WASTE CONTRIBUTION

The draft permit includes pretreatment requirements that are appropriate for a facility of this size and complexity. The City of Kyle WWTP does appear to receive significant industrial wastewater contributions. The WWTP receives process wastewater from two significant industrial users (SIUs). The process wastewater flow from the SIU contributes less than 0.3% of the WWTP's current maximum hydraulic capacity. The POTW has not experienced any instances of pass through or interference, therefore, at this time, the TCEQ is not requiring the permittee to develop a pretreatment program.

#### 6. SUMMARY OF SELF-REPORTED EFFLUENT ANALYSES

The following is a summary of the applicant's effluent monitoring data for the period March 2017 through April 2022. The average of Daily Average value is computed by the averaging of all 30-day average values for the reporting period for each parameter: flow, five-day carbonaceous biochemical oxygen demand (CBOD $_5$ ), total suspended solids (TSS), ammonia nitrogen (NH $_3$ -N). The average of Daily Average value for *Escherichia coli* (*E. coli*) in colony-forming units (CFU) or most probable number (MPN) per 100 ml is calculated via geometric mean.

| <u>Parameter</u>               | <u>Average of Daily Avg</u> |
|--------------------------------|-----------------------------|
| Flow, MGD                      | 2.59                        |
| CBOD <sub>5</sub> , mg/l       | 3.8                         |
| TSS, mg/l                      | 3.03                        |
| NH <sub>3</sub> -N, mg/l       | 3.3                         |
| E. coli, CFU or MPN per 100 ml | 18                          |

#### 7. DRAFT PERMIT CONDITIONS AND MONITORING REQUIREMENTS

The effluent limitations and monitoring requirements for those parameters that are limited in the draft permit are as follows:

# A. INTERIM I PHASE EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The annual average flow of effluent shall not exceed 4.5 MGD, nor shall the average discharge during any two-hour period (2-hour peak) exceed 12,500 gallons per minute (gpm).

| <u>Parameter</u>    | 30-Day Average |                | <u>7-Day</u>   | <u>Daily</u>   |
|---------------------|----------------|----------------|----------------|----------------|
|                     |                |                | <u>Average</u> | <u>Maximum</u> |
|                     | <u>mg/l</u>    | <u>lbs/day</u> | <u>mg/l</u>    | <u>mg/l</u>    |
| $\mathrm{CBOD}_5$   | 10             | 375            | 15             | 25             |
| TSS                 | 15             | 563            | 25             | 40             |
| $NH_3$ - $N$        | 2              | 75             | 5              | 10             |
| DO (minimum)        | 5.0            | N/A            | N/A            | N/A            |
| E. coli, CFU or MPN | 126            | N/A            | N/A            | 399            |
| per 100 ml          |                |                |                |                |

The pH shall not be less than 6.5 standard units nor greater than 9.0 standard units and shall be monitored once per week by grab sample. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.

The permittee shall utilize an Ultraviolet Light (UV) system for disinfection purposes. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.

| <u>Parameter</u>   | Monitoring Requirement |
|--------------------|------------------------|
| Flow, MGD          | Continuous             |
| $CBOD_5$           | Two/week               |
| TSS                | Two/week               |
| NH <sub>3</sub> -N | Two/week               |
| DO                 | Two/week               |
| E. coli            | Daily                  |

# B. INTERIM II PHASE EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The annual average flow of effluent shall not exceed 9.0 MGD, nor shall the average discharge during any two-hour period (2-hour peak) exceed 25,000 gpm.

| <u>Parameter</u> | <u>30-Day Average</u> |                | <u>7-Day</u>   | <u>Daily</u>   |
|------------------|-----------------------|----------------|----------------|----------------|
|                  |                       |                | <u>Average</u> | <u>Maximum</u> |
|                  | <u>mg/l</u>           | <u>lbs/day</u> | <u>mg/l</u>    | <u>mg/l</u>    |
| $CBOD_5$         | 7                     | 525            | 12             | 22             |
| TSS              | 15                    | 1,126          | 15             | 40             |
| $NH_3$ -N        | 2                     | 150            | 5              | 10             |
| Total Phosphorus | 0.5                   | 38             | 1              | 2              |
| DO (minimum)     | 5.0                   | N/A            | N/A            | N/A            |
| E. coli, CFU or  | 126                   | N/A            | N/A            | 399            |
| MPN/100 ml       |                       |                |                |                |

The pH shall not be less than 6.5 standard units nor greater than 9.0 standard units and shall be monitored five times per week by grab sample. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.

The permittee shall utilize an Ultraviolet Light (UV) system for disinfection purposes. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.

| <u>Parameter</u> | Monitoring Requirement |
|------------------|------------------------|
| Flow, MGD        | Continuous             |
| $CBOD_5$         | Five/Week              |
| TSS              | Five/Week              |
| $NH_3$ -N        | Five/Week              |
| Total P          | Five/Week              |
| DO               | Five/Week              |
| E. coli          | Daily                  |

# C. FINAL PHASE EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

The annual average flow of effluent shall not exceed 12.0 MGD, nor shall the average discharge during any two-hour period (2-hour peak) exceed 39,344 gpm.

| <u>Parameter</u>  | 30-Day Average |                | <u>7-Day</u>   | <u>Daily</u>   |
|-------------------|----------------|----------------|----------------|----------------|
|                   |                |                | <u>Average</u> | <u>Maximum</u> |
|                   | <u>mg/l</u>    | <u>lbs/day</u> | mg/l           | <u>mg/l</u>    |
| $\mathrm{CBOD}_5$ | 5              | 500            | 10             | 20             |
| TSS               | 15             | 1,053          | 15             | 40             |
| $NH_3$ -N         | 2              | 200            | 5              | 10             |
| Total Phosphorus  | 0.5            | 50             | 1              | 2              |
| DO (minimum)      | 5.0            | N/A            | N/A            | N/A            |
| E. coli, CFU or   | 126            | N/A            | N/A            | 399            |
| MPN/100 ml        |                |                |                |                |

The pH shall not be less than 6.5 standard units nor greater than 9.0 standard units and shall be monitored once per day by grab sample. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.

The permittee shall utilize an Ultraviolet Light (UV) system for disinfection purposes. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.

| <u>Parameter</u> | Monitoring Requirement |
|------------------|------------------------|
| Flow, MGD        | Continuous             |
| $CBOD_5$         | One/day                |
| TSS              | One/day                |
| $NH_3$ - $N$     | One/day                |
| Total P          | One/day                |
| DO               | One/day                |
| E. coli          | Daily                  |

#### C. SEWAGE SLUDGE REQUIREMENTS

The draft permit includes Sludge Provisions according to the requirements of 30 TAC Chapter 312, Sludge Use, Disposal, and Transportation. The draft permit also authorizes the disposal of sludge at a TCEQ-authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge.

#### D. PRETREATMENT REQUIREMENTS

Permit requirements for pretreatment are based on TPDES regulations contained in 30 TAC Chapter 315, which references 40 Code of Federal Regulations (CFR) Part 403, "General Pretreatment Regulations for Existing and New Sources of Pollution" [rev. Federal Register/Vol. 70/No. 198/Friday, October 14, 2005/Rules and Regulations, pages 60134-60798]. The permit includes specific requirements that establish responsibilities of local government, industry, and the public to implement the standards to control pollutants which pass through or interfere with treatment processes in publicly owned treatment works or which may contaminate the sewage sludge. This permit has appropriate pretreatment language for a facility of this size and complexity.

#### E. WHOLE EFFLUENT TOXICITY (BIOMONITORING) REQUIREMENTS

- (1) The draft permit includes chronic freshwater biomonitoring requirements as follows. The permit requires five dilutions in addition to the control (0% effluent) to be used in the toxicity tests. These additional effluent concentrations shall be 32%, 42%, 56%, 75%, and 100%. The low-flow effluent concentration (critical dilution) is defined as 100% effluent. The critical dilution is in accordance with the "Aquatic Life Criteria" section of the "Water Quality Based Effluent Limitations/Conditions" section.
  - (a) Chronic static renewal survival and reproduction test using the water flea (*Ceriodaphnia dubia*). The frequency of the testing is once per quarter for at least the first year of testing, after which the permittee may apply for a testing frequency reduction.
  - (b) Chronic static renewal 7-day larval survival and growth test using the fathead minnow (*Pimephales promelas*). The frequency of the testing is once per quarter for at least the first year of testing, after which the permittee may apply for a testing frequency reduction.
- (2) The draft permit includes the following minimum 24-hour acute freshwater biomonitoring requirements at a frequency of once per six months:
  - (a) Acute 24-hour static toxicity test using the water flea (*Daphnia pulex* or *Ceriodaphnia dubia*).
  - (b) Acute 24-hour static toxicity test using the fathead minnow (*Pimephales promelas*).

#### H. SUMMARY OF CHANGES FROM APPLICATION

None.

#### I. SUMMARY OF CHANGES FROM EXISTING PERMIT

The draft permit will be issued to expire **three years from the date of issuance**. Due to two chronic failures by each test species occurring during the term of the existing permit, the permit will be issued for a three-year term, based on recommendations from the WQ Standards Implementation Team.

The Standard Permit Conditions, Sludge Provisions, Other Requirements, and Biomonitoring sections of the draft permit have been updated.

For Publicly Owned Treatment Works (POTWs), effective December 21, 2025, the permittee must submit the written report for unauthorized discharges and unanticipated bypasses that exceed any effluent limit in the permit using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver.

Effective December 21, 2025, the permittee must submit the annual sludge report using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. The Reporting Requirements of the Sludge Provisions have also been updated.

Certain accidental discharges or spills of treated or untreated was tewater from wastewater treatment facilities or collection systems owned or operated by a local government may be reported on a monthly basis in accordance with 30 TAC  $\S$  305.132.

Total Phosphorus limits of 0.5 mg/L have been placed in the permit in the Interim II and Final phases, based on recommendations by the WQ Standards Implementation Team.

The Interim I & II and Final phases have been placed in the permit to transition the annual average flow limits from 4.5 MGD to 12.0 MGD.

The draft permit includes all updates based on the 30 TAC § 312 rule change effective April 23, 2020.

#### 8. DRAFT PERMIT RATIONALE

#### A. TECHNOLOGY-BASED EFFLUENT LIMITATIONS/CONDITIONS

Regulations promulgated in Title 40 of the CFR require that technology-based limitations be placed in wastewater discharge permits based on effluent limitations guidelines, where applicable, or on best professional judgment (BPJ) in the absence of guidelines.

Effluent limitations for maximum and minimum pH are in accordance with 40 CFR § 133.102(c) and 30 TAC § 309.1(b).

Texas Surface Water Quality Standards (TSWQS) at 30 TAC Chapter 307 allow for consideration of the mixing of effluent and receiving water when evaluating discharge compliance with water quality criteria for pH. The discharge authorized by this permit shall meet the TSWQS pH criterion for Segment No. 1810 of 6.5 to 9.0 standard units at the edge of the chronic mixing zone. See Attachment A of this Fact Sheet.

#### B. WATER QUALITY SUMMARY AND COASTAL MANAGEMENT PLAN

#### (1) WATER QUALITY SUMMARY

The treated effluent is discharged directly to Plum Creek in Segment No. 1810 of the Guadalupe River Basin. The designated uses for Segment No. 1810 are primary contact recreation, aquifer protection, and high aquatic life use. In accordance with 30 Texas Administrative Code §307.5 and the TCEQ implementation procedures (June 2010) for the Texas Surface Water Quality Standards, an antidegradation review of the receiving waters was performed. A Tier 1 antidegradation review has preliminarily determined that existing water quality uses will not be impaired by this permit action. Numerical and narrative criteria to protect existing uses will be maintained. A Tier 2 review has preliminarily determined that no significant degradation of water quality is expected in Plum Creek, which has been identified as having high aquatic life use. Existing uses will be maintained and protected. The preliminary determination can be reexamined and may be modified if new information is received.

The discharge from this permit action is not expected to have an effect on any federal endangered or threatened aquatic or aquatic-dependent species or proposed species or their critical habitat. This determination is based on the United States Fish and Wildlife Service's (USFWS's) biological opinion on the State of Texas authorization of the TPDES (September 14, 1998; October 21, 1998, update). To make this determination for TPDES permits, TCEQ and EPA only considered aquatic or aquatic-dependent species occurring in watersheds of critical concern or high priority as listed in Appendix A of the USFWS biological opinion. The determination is subject to reevaluation due to subsequent updates or amendments to the biological opinion. The permit does not require EPA review with respect to the presence of endangered or threatened species.

Segment No. 1810 is not currently listed on the state's inventory of impaired and threatened waters (the 2020 CWA § 303(d) list).

The pollutant analysis of treated effluent provided by the permittee in the application indicated 872 mg/l total dissolved solids (TDS), 104 mg/l sulfate, and 241 mg/l chloride present in the effluent. The segment criteria for Segment No. 1810 are 1,120 mg/l for TDS, 150 mg/l for sulfate, and 350mg/l for chlorides. Based on dissolved solids screening, no additional limits or monitoring requirements are needed for total dissolved solids, chloride, or sulfate. See Attachment B of this Fact Sheet.

The effluent limitations and conditions in the draft permit comply with EPA-approved portions of the 2018 Texas Surface Water Quality Standards (TSWQS), 30 TAC §§ 307.1 - 307.10, effective March 1, 2018; 2014 TSWQS, effective March 6, 2014; 2010 TSWQS, effective July 22, 2010; and 2000 TSWQS, effective July 26, 2000.

#### (2) CONVENTIONAL PARAMETERS

Effluent limitations for the conventional effluent parameters (i.e., Five-Day Biochemical Oxygen Demand or Five-Day Carbonaceous Biochemical Oxygen Demand, Ammonia Nitrogen, etc.) are based on stream standards and waste load allocations for water quality-limited streams as established in the TSWQS and the State of Texas Water Quality Management Plan (WQMP).

The effluent limitations in the draft permit have been reviewed for consistency with the WQMP. The proposed effluent limitations are not contained in the approved WQMP. However, these limits will be included in the next WQMP update.

The effluent limitations in the draft permit meet the requirements for secondary treatment and the requirements for disinfection according to 30 TAC Chapter 309, Subchapter A: Effluent Limitations.

#### (3) COASTAL MANAGEMENT PLAN

The facility is not located in the Coastal Management Program boundary.

#### C. WATER QUALITY-BASED EFFLUENT LIMITATIONS/CONDITIONS

#### (1) GENERAL COMMENTS

The Texas Surface Water Quality Standards (30 TAC Chapter 307) state that surface waters will not be toxic to man, or to terrestrial or aquatic life. The methodology outlined in the *Procedures to Implement the Texas Surface Water Quality Standards*, (IP) (June 2010) is designed to ensure compliance with 30 TAC Chapter 307. Specifically, the methodology is designed to ensure that no source will be allowed to discharge any wastewater that: (1) results in instream aquatic toxicity; (2) causes a violation of an applicable narrative or numerical state water quality standard; (3) results in the endangerment of a drinking water supply; or (4) results in aquatic bioaccumulation that threatens human health.

#### (2) AQUATIC LIFE CRITERIA

#### (a) SCREENING

Water quality-based effluent limitations are calculated from freshwater aquatic life criteria found in Table 1 of the Texas Surface Water Quality Standards (30 TAC Chapter 307).

Acute freshwater criteria are applied at the edge of the zone of initial dilution (ZID), and chronic freshwater criteria are applied at the edge of the aquatic life mixing zone. The ZID for this discharge is defined as 20 feet upstream and 60 feet downstream from the point where the discharge enters Plum Creek. The aquatic life mixing zone for this discharge is defined as 100 feet upstream and 300 feet downstream from the point where the discharge enters Plum Creek.

TCEQ uses the mass balance equation to estimate dilutions at the edges of the ZID and aquatic life mixing zone during critical conditions. The estimated dilution at the edge of the aquatic life mixing zone is calculated using the permitted flow of 12 MGD and the 7-day, 2-year (7Q2) flow of 0.1 cubic feet per second (cfs) for Plum Creek. The estimated dilution at the edge of the ZID is calculated using the permitted flow of 12.0 MGD and 25% of the 7Q2 flow. The following critical effluent percentages are being used:

Acute Effluent %: 99.46% Chronic Effluent %: 99.87%

Waste load allocations (WLAs) are calculated using the above estimated effluent percentages, criteria outlined in the Texas Surface Water Quality Standards, and partitioning coefficients for metals (when appropriate and designated in the implementation procedures). The WLA is the end-of-pipe effluent concentration that can be discharged when, after mixing in the receiving stream, instream numerical criteria will not be exceeded.

From the WLA, a long-term average (LTA) is calculated using a log normal probability distribution, a given coefficient of variation (0.6), and a 90<sup>th</sup> percentile confidence level. The LTA is the long-term average effluent concentration for which the WLA will never be exceeded using a selected percentile confidence level. The lower of the two LTAs (acute and chronic) is used to calculate a daily average and daily maximum effluent limitation for the protection of aquatic life using the same statistical considerations with the 99<sup>th</sup> percentile confidence level and a standard number of monthly effluent samples collected (12). Assumptions used in deriving the effluent limitations include segment values for hardness, chlorides, pH, and total suspended solids (TSS) according to the segmentspecific values contained in the TCEQ guidance document IP. The segment values are 215 mg/l for hardness (as calcium carbonate), 135 mg/l chlorides, 7.6 standard units for pH, and 12 mg/l for TSS. For additional details on the calculation of water quality-based effluent limitations, refer to the TCEQ guidance document.

TCEQ practice for determining significant potential is to compare the reported analytical data against percentages of the calculated daily average water quality-based effluent limitation. Permit limitations are required when analytical data reported in the application exceeds 85% of the calculated daily average water quality-based effluent limitation. Monitoring and reporting is required when analytical data reported in the application exceeds 70% of the calculated daily average water quality-based effluent limitation. See Attachment C of this Fact Sheet.

#### (b) PERMIT ACTION

Reported analytical data does not exceed 70% of the calculated daily average water quality-based effluent limitations for aquatic life protection.

#### (3) AQUATIC ORGANISM BIOACCUMULATION CRITERIA

#### (a) SCREENING

Water quality-based effluent limitations for the protection of human health are calculated using criteria for the consumption of freshwater fish tissue found in Table 2 of the Texas Surface Water Quality Standards (30 TAC Chapter 307). Freshwater fish tissue bioaccumulation criteria are applied at the edge of the human health mixing zone. The human health mixing zone for this discharge is identical to the aquatic life mixing zone. TCEQ uses the mass balance equation to estimate dilution at the edge of the human health mixing zone during average flow conditions. The estimated dilution at the edge of the human health mixing zone is calculated using the permitted flow of 12 MGD and the harmonic mean flow of 0.2 cfs for Plum Creek. The following critical effluent percentage is being used:

Human Health Effluent %: 98.93%

#### (b) PERMIT ACTION

Reported analytical data does not exceed 70% of the calculated daily average water quality-based effluent limitation for human health protection.

#### (4) DRINKING WATER SUPPLY PROTECTION

#### (a) SCREENING

Water Quality Segment No. 1810, which receives the discharge from this facility, is not designated as a public water supply. Screening reported analytical data of the effluent against water quality-based effluent limitations calculated for the protection of a drinking water supply is not applicable.

#### (b) PERMIT ACTION

None.

#### (5) WHOLE EFFLUENT TOXICITY (BIOMONITORING) CRITERIA

#### (a) SCREENING

TCEQ has determined that there may be pollutants present in the effluent that may have the potential to cause toxic conditions in the receiving

stream. Whole effluent biomonitoring is the most direct measure of potential toxicity that incorporates the effects of synergism of effluent components and receiving stream water quality characteristics. Biomonitoring of the effluent is, therefore, required as a condition of this permit to assess potential toxicity.

The existing permit includes chronic freshwater biomonitoring requirements. A summary of the biomonitoring testing for the facility indicates that in the past three years, the permittee performed twenty-eight chronic tests, with four demonstrations of significant toxicity (i.e., four failures), two by each test species.

A reasonable potential (RP) determination was performed for the in accordance with 40 CFR § 122.44(d)(1)(ii) to determine whether the discharge will reasonably be expected to cause or contribute to an exceedance of a state water quality standard or criterion within that standard. The RP determination is based on representative data from the previous three years of chronic WET testing. This determination was performed in accordance with the methodology outlined in the TCEQ letter to the EPA dated December 28, 2015, and approved by the EPA in a letter dated December 28, 2015.

With two failures by each test species, a three-year permit will be issued in accordance with the methodology referenced above. Neither test species is eligible for the testing frequency reduction.

After permit issuance and upon another failure (i.e., another demonstration of significant toxicity), the testing frequency for that test species will increase to monthly until three consecutive tests pass (i.e., do not demonstrate significant toxicity), at which time the permittee may return to the quarterly testing frequency. If three or more failures are demonstrated during the three-year permit term for either test species, RP will have been demonstrated and a WET limit will be included in the subsequently reissued permit for that test species.

#### (b) PERMIT ACTION

The test species are appropriate to measure the toxicity of the effluent consistent with the requirements of the State water quality standards. The biomonitoring frequency has been established to reflect the likelihood of ambient toxicity and to provide data representative of the toxic potential of the facility's discharge. This permit may be reopened to require effluent limits, additional testing, and/or other appropriate actions to address toxicity if biomonitoring data show actual or potential ambient toxicity to be the result of the permittee's discharge to the receiving stream or water body.

#### (6) WHOLE EFFLUENT TOXICITY CRITERIA (24-HOUR ACUTE)

#### (a) SCREENING

The existing permit includes 24-hour acute freshwater biomonitoring language. A summary of the biomonitoring testing for the facility indicates that in the past three years, the permittee has performed ten 24-hour acute tests, with zero demonstrations of significant lethality (i.e., zero failures).

#### (b) PERMIT ACTION

The draft permit includes 24-hour 100% acute biomonitoring tests for the life of the permit.

#### 9. WATER QUALITY VARIANCE REQUESTS

No variance requests have been received.

#### 10. PROCEDURES FOR FINAL DECISION

When an application is declared administratively complete, the Chief Clerk sends a letter to the applicant advising the applicant to publish the Notice of Receipt of Application and Intent to Obtain Permit in the newspaper. In addition, the Chief Clerk instructs the applicant to place a copy of the application in a public place for review and copying in the county where the facility is or will be located. This application will be in a public place throughout the comment period. The Chief Clerk also mails this notice to any interested persons and, if required, to landowners identified in the permit application. This notice informs the public about the application and provides that an interested person may file comments on the application or request a contested case hearing or a public meeting.

Once a draft permit is completed, it is sent, along with the Executive Director's preliminary decision, as contained in the technical summary or fact sheet, to the Chief Clerk. At that time, the Notice of Application and Preliminary Decision will be mailed to the same people and published in the same newspaper as the prior notice. This notice sets a deadline for making public comments. The applicant must place a copy of the Executive Director's preliminary decision and draft permit in the public place with the application.

Any interested person may request a public meeting on the application until the deadline for filing public comments. A public meeting is intended for the taking of public comment and is not a contested case proceeding.

After the public comment deadline, the Executive Director prepares a response to all significant public comments on the application or the draft permit raised during the public comment period. The Chief Clerk then mails the Executive Director's response to comments and final decision to people who have filed comments, requested a contested case hearing, or requested to be on the mailing list. This notice provides that if a person is not satisfied with the Executive Director's response and decision, they can request a contested case hearing or file a request to reconsider the Executive Director's decision within 30 days after the notice is mailed.

The Executive Director will issue the permit unless a written hearing request or request for reconsideration is filed within 30 days after the Executive Director's response to comments and final decision is mailed. If a hearing request or request for

reconsideration is filed, the Executive Director will not issue the permit and will forward the application and request to the TCEQ Commissioners for their consideration at a scheduled Commission meeting. If a contested case hearing is held, it will be a legal proceeding similar to a civil trial in state district court.

If the Executive Director calls a public meeting or the Commission grants a contested case hearing as described above, the Commission will give notice of the date, time, and place of the meeting or hearing. If a hearing request or request for reconsideration is made, the Commission will consider all public comments in making its decision and shall either adopt the Executive Director's response to public comments or prepare its own response.

For additional information about this application, contact Sonia Bhuiya at (512) 239-1205.

#### 11. ADMINISTRATIVE RECORD

The following items were considered in developing the draft permit:

#### A. PERMIT(S)

TPDES Permit No. WQ0011041002 issued on October 6, 2020.

#### B. APPLICATION

Application received on March 11, 2022, and additional information received on April 11, 2022. Staff initiated minor amendment started on XXX date.

#### C. MEMORANDA

Interoffice Memoranda from the Water Quality Assessment Section of the TCEQ Water Quality Division. Interoffice Memorandum from the Pretreatment Team of the TCEQ Water Quality Division.

#### D. MISCELLANEOUS

Federal Clean Water Act § 402; Texas Water Code § 26.027; 30 TAC Chapters 30, 305, 309, 312, and 319; Commission policies; and U.S. Environmental Protection Agency guidelines.

Texas Surface Water Quality Standards, 30 TAC §§ 307.1 - 307.10.

Procedures to Implement the Texas Surface Water Quality Standards (IP), Texas Commission on Environmental Quality, June 2010, as approved by the U.S. Environmental Protection Agency, and the IP, January 2003, for portions of the 2010 IP not approved by the U.S. Environmental Protection Agency.

Texas 2020 Clean Water Act Section 303(d) List, Texas Commission on Environmental Quality, March 25, 2020; approved by the U.S. Environmental Protection Agency on May 12, 2020.

Texas Natural Resource Conservation Commission, Guidance Document for Establishing Monitoring Frequencies for Domestic and Industrial Wastewater Discharge Permits, Document No. 98-001.000-OWR-WQ, May 1998.

## **Attachment A: pH Screening**

Calculation of pH of a mixture of two flows. Based on the procedure in EPA's DESCON program (EPA, 1988. Technical Guidance on Supplementary Stream Design Conditions for Steady State Modeling. USEPA Office of Water, Washington D.C.)

City of Kyle (WWTP)

pH Screening - 11041-002

| INPUT                                      |                   |                    |   |
|--|-------------------|--------------------|---|
|  | Lower<br>pH limit | Higher<br>pH limit | Data source<br>and notes<br>Reciprocal of the<br>effluent fraction.   |
| 1. DILUTION FACTOR AT MIXING ZONE BOUNDARY | 1.005             | 1.005              | Calculated from values in critical conditions memo dated 3/2022   |
| RECEIVING WATER<br>CHARACTERISTICS         |                   |                    |   |
| 2. Temperature (deg C):                    | 20.00             | 20.00              | Range of<br>temperatures<br>tested (5 to 35<br>degrees C)   |
| 3. pH:                                     | 7.6               | 7.6                | Ambient pH for<br>Segment 1810<br>from 2010 IPs.<br>Hardness for  |
| 4. Alkalinity (mg CaCO3/L):                | 215.00            | 215.00             | Segment 1810 from IPs.  |
| EFFLUENT CHARACTERISTICS                   |                   |                    |   |
| 5. Temperature (deg C):                    | 20.00             | 20.00              | Range of<br>temperatures<br>tested (5 to 35<br>degrees C)   |
| 6. pH:                                     | 6.00              | 9.00               | Proposed permit limit.  |
| 7. Alkalinity (mg CaCO3/L):*               | 20.00             | 200.00             | Range of values<br>tested (50 - 500<br>mg/L CaCO3).<br>Note that default<br>of 20 is used for<br>low pH situations. |

#### **OUTPUT**

| 1. IONIZATION CONSTANTS                                  |                 |                 |
|--|-----------------|-----------------|
| Upstream/Background pKa:                                 | 6.3<br>8        | 6.3<br>8        |
|  | 6.3             | 6.3             |
| Effluent pKa:  | 8               | 8               |
| 2. IONIZATION FRACTIONS                                  | 0.0             | 0.0             |
| Upstream/Background Ionization Fraction:                 | 0.9<br>4<br>0.2 | 0.9<br>4<br>1.0 |
| Effluent Ionization Fraction:                            | 9               | 0               |
| 3. TOTAL INORGANIC CARBON                                | 220             | 220             |
| Upstream/Background Total Inorganic Carbon (mg CaCO3/L): | .01             | .01             |
| Effluent Total Ingrapia Carbon (mg CaCO2/L)              | 68.             | 200<br>.48      |
| Effluent Total Inorganic Carbon (mg CaCO3/L):            | 20              | .40             |
| 4. CONDITIONS AT MIXING ZONE BOUNDARY                    |                 |                 |
| Temperature (deg C):                                     | 20.<br>00       | 20.<br>00       |
| remperature (deg C).                                     | 21.             | 200             |
| Alkalinity (mg CaCO3/L):                                 | 04              | .08             |
| Total Inorganic Carbon (mg CaCO3/L):                     | 69.<br>05       | 200<br>.63      |
|  | 6.3             | 6.3             |
| pKa:   | 8               | 8               |
|  |                 |                 |
|  | 6.0             | 8.9             |

<sup>\*</sup> Assume minimal total alkalinity at low effluent pH based on carbonate equilibrium chemistry of natural and treated waters

# Attachment B: Screening Calculations for Total Dissolved Solids, Chloride, and Sulfate

# Screening Calculations for Total Dissolved Solids, Chloride, and Sulfate Menu 3 - Discharge to a Perennial Stream or River

Applicant Name:

City of Kyle (WWTP)

Permit Number, Outfall:

Segment Number:

1810

| Enter values needed for screening:             |        |      | Data Source (edit if different) |
|--|--------|------|---------------------------------|
| QE - Average effluent flow                     | 4.5    | MGD  |                                 |
| QS - Perennial stream harmonic mean flow       | 0.20   | cfs  | 2019 Critical conditions memo   |
| QE - Average effluent flow                     | 6.9625 | cfs  | Calculated                      |
|  |        |      |                                 |
| CA - TDS - ambient segment concentration       | 673    | mg/L | 2010 IP, Appendix D             |
| CA - chloride - ambient segment concentration  | 135    | mg/L | 2010 IP, Appendix D             |
| CA - sulfate - ambient segment concentration   | 85     | mg/L | 2010 IP, Appendix D             |
|  |        |      |                                 |
| CC - TDS - segment criterion                   | 1120   | mg/L | 2014 TSWQS, Appendix A          |
| CC - chloride - segment criterion              | 350    | mg/L | 2014 TSWQS, Appendix A          |
| CC - sulfate - segment criterion               | 150    | mg/L | 2014 TSWQS, Appendix A          |
|  |        | -    |                                 |
| CE - TDS - average effluent concentration      | 872    | mg/L | Permit application              |
| CE - chloride - average effluent concentration | 241    | mg/L | Permit application              |
| CE - sulfate - average effluent concentration  | 104    | mg/L | Permit application              |

#### **Screening Equation**

 $CC \ge [(QS)(CA) + (QE)(CE)]/[QE + QS]$ 

#### **Permit Limit Calculations**

#### TDS

| _                                  |                         |         |  |
|------------------------------------|-------------------------|---------|--|
|                                    | WLA= [CC(QE+QS) -       |         |  |
| Calculate the WLA                  | (QS)(CA)]/QE            | 1132.84 |  |
| Calculate the LTA                  | LTA = WLA * 0.93        | 1053.54 |  |
| Calculate the daily average        | Daily Avg. = LTA * 1.47 | 1548.71 |  |
| Calculate the daily maximum        | Daily Max. = LTA * 3.11 | 3276.51 |  |
|                                    | 70% of Daily Avg.       |         |  |
| Calculate 70% of the daily average | =                       | 1084.09 |  |
|                                    | 85% of Daily Avg.       |         |  |
| Calculate 85% of the daily average | =                       | 1316.40 |  |

| No permit limitations needed if: | 872 | ≤ | 1084.09 |       |         |
|----------------------------------|-----|---|---------|-------|---------|
| Reporting needed if:             | 872 | > | 1084.09 | but ≤ | 1316.40 |
| Permit limits may be needed if:  | 872 | > | 1316.40 |       |         |

## No permit limitations needed for TDS

#### Chloride

| Chloride                           |                   |         |        |         |        |
|------------------------------------|-------------------|---------|--------|---------|--------|
|                                    | WLA= [CC(C        |         | _      |         |        |
| Calculate the WLA                  | (QS)(CA)]/Q       | ĮΕ      |        | 356.18  |        |
| Calculate the LTA                  | LTA = WLA '       | * 0.93  |        | 331.24  |        |
| Calculate the daily average        | Daily Avg. =      | LTA * 1 | L.47   | 486.93  |        |
| Calculate the daily maximum        | Daily Max. =      | = LTA * | 3.11   | 1030.17 |        |
|                                    | 70% of Daily Avg. |         |        |         |        |
| Calculate 70% of the daily average | =                 |         |        | 340.85  |        |
|                                    | 85% of Daily      | y Avg.  |        |         |        |
| Calculate 85% of the daily average | =                 |         |        | 413.89  |        |
|                                    |                   |         |        |         |        |
| No permit limitations needed if:   | 241               | ≤       | 340.85 |         |        |
| Reporting needed if:               | 241               | >       | 340.85 | but ≤   | 413.89 |
| Permit limits may be needed if:    | 241               | >       | 413.89 |         |        |

## No permit limitations needed for chloride

### Sulfate

| Permit limits may be needed if:    | 104 > 176.47                          |   |
|------------------------------------|---------------------------------------|---|
| Reporting needed if:               | 104 > 145.33 but ≤ 176.4              | 7 |
| No permit limitations needed if:   | 104 ≤ 145.33                          |   |
| , 5                                |                                       |   |
| Calculate 85% of the daily average | = 176.47                              |   |
| Calculate 70% of the daily average | 85% of Daily Avg.                     |   |
| Calculate 70% of the daily average | 70% of Daily Avg.                     |   |
| Calculate the daily maximum        | Daily Max. = LTA * 3.11 <b>439.25</b> |   |
| Calculate the daily average        | Daily Avg. = LTA * 1.47 <b>207.62</b> |   |
| Calculate the LTA                  | LTA = WLA * 0.93 141.24               |   |
| Calculate the WLA                  | (QS)(CA)]/QE 151.87                   |   |
|                                    | WLA= [CC(QE+QS) -                     |   |

## No permit limitations needed for sulfate

## **Attachment C: Calculated Water Quality Based Effluent Limitations**

#### **TEXTOX MENU #3 - PERENNIAL STREAM OR RIVER**

The water quality-based effluent limitations developed below are calculated using:

Table 1, 2014 Texas Surface Water Quality Standards (30 TAC 307) for Freshwater Aquatic Life

Table 2, 2018 Texas Surface Water Quality Standards for Human Health

"Procedures to Implement the Texas Surface Water Quality Standards," TCEQ, June 2010

#### PERMIT INFORMATION

| Permittee Name:   | City of Kyle  |
|-------------------|---------------|
| TPDES Permit No.: | WQ0011041002  |
| Outfall No.:      | 001           |
| Prepared by:      | Sonia Bhuiya  |
| Date:             | July 11, 2022 |

#### DISCHARGE INFORMATION

| Receiving Waterbody:                          | Plum Creek |  |
|---|------------|--|
| Segment No.:                                  | 1810       |  |
| TSS (mg/L):                                   | 12         |  |
| pH (Standard Units):                          | 7.6        |  |
| Hardness (mg/L as CaCO <sub>3</sub> ):        | 215        |  |
| Chloride (mg/L):                              | 135        |  |
| Effluent Flow for Aquatic Life (MGD):         | 12         |  |
| Critical Low Flow [7Q2] (cfs):                | 0.1        |  |
| % Effluent for Chronic Aquatic Life (Mixing   |            |  |
| Zone):  | 99.46      |  |
| % Effluent for Acute Aquatic Life (ZID):      | 99.87      |  |
| Effluent Flow for Human Health (MGD):         | 12         |  |
| Harmonic Mean Flow (cfs):                     | 0.2        |  |
| % Effluent for Human Health:                  | 98.93      |  |
| Human Health Criterion (select: PWS, FISH, or |            |  |
| INC)  | FISH       |  |

#### CALCULATE DISSOLVED FRACTION (AND ENTER WATER EFFECT RATIO IF APPLICABLE):

| Stream/River Metal    | Intercept<br>(b) | Slope<br>(m) | Partition<br>Coefficient<br>(Kp) | Dissolved<br>Fraction<br>(Cd/Ct) | Source  | Water<br>Effect<br>Ratio<br>(WER) | Source  |
|-----------------------|------------------|--------------|----------------------------------|----------------------------------|---------|-----------------------------------|---------|
| Aluminum              | N/A              | N/A          | N/A                              | 1.00                             | Assumed | 1.00                              | Assumed |
| Arsenic               | 5.68             | -0.73        | 78018.52                         | 0.516                            |         | 1.00                              | Assumed |
| Cadmium               | 6.60             | -1.13        | 240173.56                        | 0.258                            |         | 1.00                              | Assumed |
| Chromium (total)      | 6.52             | -0.93        | 328368.46                        | 0.202                            |         | 1.00                              | Assumed |
| Chromium (trivalent)  | 6.52             | -0.93        | 328368.46                        | 0.202                            |         | 1.00                              | Assumed |
| Chromium (hexavalent) | N/A              | N/A          | N/A                              | 1.00                             | Assumed | 1.00                              | Assumed |
| Copper                | 6.02             | -0.74        | 166496.80                        | 0.334                            |         | 1.00                              | Assumed |
| Lead                  | 6.45             | -0.80        | 386060.17                        | 0.178                            |         | 1.00                              | Assumed |
| Mercury               | N/A              | N/A          | N/A                              | 1.00                             | Assumed | 1.00                              | Assumed |
| Nickel                | 5.69             | -0.57        | 118813.75                        | 0.412                            |         | 1.00                              | Assumed |
| Selenium              | N/A              | N/A          | N/A                              | 1.00                             | Assumed | 1.00                              | Assumed |
| Silver                | 6.38             | -1.03        | 185542.46                        | 0.310                            |         | 1.00                              | Assumed |
| Zinc                  | 6.10             | -0.70        | 221092.05                        | 0.274                            |         | 1.00                              | Assumed |

#### AQUATIC LIFE

CALCULATE DAILY AVERAGE AND DAILY MAXIMUM EFFLUENT LIMITATIONS:

| Parameter                               | FW Acute<br>Criterion<br>(μg/L) | FW<br>Chronic<br>Criterion<br>(μg/L) | WLAα<br>(μg/L) | WLAc<br>(μg/L) | LTAα<br>(μg/L) | LTAc<br>(μg/L) | Daily Avg.<br>(μg/L) | Daily<br>Max.<br>(μg/L) |
|---|---------------------------------|--------------------------------------|----------------|----------------|----------------|----------------|----------------------|-------------------------|
| Aldrin                                  | 3.0                             | N/A                                  | 3.00           | N/A            | 1.72           | N/A            | 2.53                 | 5.35                    |
| Aluminum                                | 991                             | N/A                                  | 992            | N/A            | 569            | N/A            | 835                  | 1768                    |
| Arsenic                                 | 340                             | 150                                  | 659            | 292            | 378            | 225            | 330                  | 699                     |
| Cadmium                                 | 18.1                            | 0.418                                | 70.2           | 1.63           | 40.2           | 1.26           | 1.84                 | 3.91                    |
| Carbaryl                                | 2.0                             | N/A                                  | 2.00           | N/A            | 1.15           | N/A            | 1.68                 | 3.56                    |
| Chlordane                               | 2.4                             | 0.004                                | 2.40           | 0.00402        | 1.38           | 0.00310        | 0.00455              | 0.00963                 |
| Chlorpyrifos                            | 0.083                           | 0.041                                | 0.0831         | 0.0412         | 0.0476         | 0.0317         | 0.0466               | 0.0987                  |
| Chromium (trivalent)                    | 1067                            | 139                                  | 5276           | 689            | 3023           | 531            | 779                  | 1650                    |
| Chromium (hexavalent)                   | 15.7                            | 10.6                                 | 15.7           | 10.7           | 9.01           | 8.21           | 12.0                 | 25.5                    |
| Copper                                  | 29.2                            | 18.2                                 | 87.7           | 54.9           | 50.2           | 42.3           | 62.1                 | 131                     |
| Cyanide (free)                          | 45.8                            | 10.7                                 | 45.9           | 10.8           | 26.3           | 8.28           | 12.1                 | 25.7                    |
| 4,4'-DDT                                | 1.1                             | 0.001                                | 1.10           | 0.00101        | 0.631          | 0.000774       | 0.00113              | 0.00240                 |
| Demeton                                 | N/A                             | 0.1                                  | N/A            | 0.101          | N/A            | 0.0774         | 0.113                | 0.240                   |
| Diazinon                                | 0.17                            | 0.17                                 | 0.170          | 0.171          | 0.0975         | 0.132          | 0.143                | 0.303                   |
| Dicofol [Kelthane]                      | 59.3                            | 19.8                                 | 59.4           | 19.9           | 34.0           | 15.3           | 22.5                 | 47.6                    |
| Dieldrin                                | 0.24                            | 0.002                                | 0.240          | 0.00201        | 0.138          | 0.00155        | 0.00227              | 0.00481                 |
| Diuron                                  | 210                             | 70                                   | 210            | 70.4           | 120            | 54.2           | 79.6                 | 168                     |
| Endosulfan I (alpha)                    | 0.22                            | 0.056                                | 0.220          | 0.0563         | 0.126          | 0.0434         | 0.0637               | 0.134                   |
| Endosulfan II (beta)                    | 0.22                            | 0.056                                | 0.220          | 0.0563         | 0.126          | 0.0434         | 0.0637               | 0.134                   |
| Endosulfan sulfate                      | 0.22                            | 0.056                                | 0.220          | 0.0563         | 0.126          | 0.0434         | 0.0637               | 0.134                   |
| Endrin                                  | 0.086                           | 0.002                                | 0.0861         | 0.00201        | 0.0493         | 0.00155        | 0.00227              | 0.00481                 |
| Guthion [Azinphos Methyl]               | N/A                             | 0.01                                 | N/A            | 0.0101         | N/A            | 0.00774        | 0.0113               | 0.0240                  |
| Heptachlor                              | 0.52                            | 0.004                                | 0.521          | 0.00402        | 0.298          | 0.00310        | 0.00455              | 0.00963                 |
| Hexachlorocyclohexane (gamma) [Lindane] | 1.126                           | 0.08                                 | 1.13           | 0.0804         | 0.646          | 0.0619         | 0.0910               | 0.192                   |
| Lead                                    | 147                             | 5.73                                 | 829            | 32.4           | 475            | 25.0           | 36.7                 | 77.6                    |
| Malathion                               | N/A                             | 0.01                                 | N/A            | 0.0101         | N/A            | 0.00774        | 0.0113               | 0.0240                  |
| Mercury                                 | 2.4                             | 1.3                                  | 2.40           | 1.31           | 1.38           | 1.01           | 1.47                 | 3.12                    |
| Methoxychlor                            | N/A                             | 0.03                                 | N/A            | 0.0302         | N/A            | 0.0232         | 0.0341               | 0.0722                  |
| Mirex                                   | N/A                             | 0.001                                | N/A            | 0.00101        | N/A            | 0.000774       | 0.00113              | 0.00240                 |
| Nickel                                  | 895                             | 99.4                                 | 2173           | 242            | 1245           | 187            | 274                  | 580                     |
| Nonylphenol                             | 28                              | 6.6                                  | 28.0           | 6.64           | 16.1           | 5.11           | 7.51                 | 15.8                    |
| Parathion (ethyl)                       | 0.065                           | 0.013                                | 0.0651         | 0.0131         | 0.0373         | 0.0101         | 0.0147               | 0.0312                  |
| Pentachlorophenol                       | 15.9                            | 12.2                                 | 16.0           | 12.3           | 9.15           | 9.47           | 13.4                 | 28.4                    |
| Phenanthrene                            | 30                              | 30                                   | 30.0           | 30.2           | 17.2           | 23.2           | 25.3                 | 53.5                    |
| Polychlorinated Biphenyls [PCBs]        | 2.0                             | 0.014                                | 2.00           | 0.0141         | 1.15           | 0.0108         | 0.0159               | 0.0337                  |
| Selenium                                | 20                              | 5                                    | 20.0           | 5.03           | 11.5           | 3.87           | 5.68                 | 12.0                    |
| Silver                                  | 0.8                             | N/A                                  | 27.9           | N/A            | 16.0           | N/A            | 23.5                 | 49.7                    |
| Toxaphene                               | 0.78                            | 0.0002                               | 0.781          | 0.000201       | 0.448          | 0.000155       | 0.000227             | 0.000481                |
| Tributyltin [TBT]                       | 0.13                            | 0.024                                | 0.130          | 0.0241         | 0.0746         | 0.0186         | 0.0273               | 0.0577                  |
| 2,4,5 Trichlorophenol                   | 136                             | 64                                   | 136            | 64.3           | 78.0           | 49.5           | 72.8                 | 154                     |
| Zinc                                    | 224                             | 226                                  | 820            | 830            | 470            | 639            | 690                  | 1461                    |

#### **HUMAN HEALTH**

CALCULATE DAILY AVERAGE AND DAILY MAXIMUM EFFLUENT LIMITATIONS:

| Parameter     | Water<br>and Fish<br>Criterion<br>(µg/L) | Fish Only<br>Criterion<br>(μg/L) | Incidental<br>Fish<br>Criterion<br>(µg/L) | WLAh<br>(μg/L) | LTAh<br>(μg/L) | Daily Avg.<br>(μg/L) | Daily Max.<br>(μg/L) |
|---------------|--|----------------------------------|---|----------------|----------------|----------------------|----------------------|
| Acrylonitrile | 1.0                                      | 115                              | 1150                                      | 116            | 108            | 158                  | 336                  |
| Aldrin        | 1.146E-05                                | 1.147E-05                        | 1.147E-04                                 | 0.0000116      | 0.0000108      | 0.0000158            | 0.0000335            |
| Anthracene    | 1109                                     | 1317                             | 13170                                     | 1331           | 1238           | 1819                 | 3850                 |
| Antimony      | 6  | 1071                             | 10710                                     | 1083           | 1007           | 1479                 | 3131                 |
| Arsenic       | 10                                       | N/A                              | N/A                                       | N/A            | N/A            | N/A                  | N/A                  |

| Barium  | 2000       | N/A           | N/A           | N/A          | N/A             | N/A             | N/A           |
|---|------------|---------------|---------------|--------------|-----------------|-----------------|---------------|
| Benzene                                       | 5          | 581           | 5810          | 587          | 546             | 802             | 1698          |
| Benzidine                                     | 0.0015     | 0.107         | 1.07          | 0.108        | 0.101           | 0.147           | 0.312         |
| Benzo(a)anthracene                            | 0.024      | 0.025         | 0.25          | 0.0253       | 0.0235          | 0.0345          | 0.0730        |
| Benzo(a)pyrene                                | 0.0025     | 0.0025        | 0.025         | 0.00253      | 0.00235         | 0.00345         | 0.00730       |
| Bis(chloromethyl)ether                        | 0.0024     | 0.2745        | 2.745         | 0.277        | 0.258           | 0.379           | 0.802         |
| Bis(2-chloroethyl)ether                       | 0.60       | 42.83         | 428.3         | 43.3         | 40.3            | 59.1            | 125           |
| Bis(2-ethylhexyl) phthalate [Di(2-ethylhexyl) |            |               |               |              |                 |                 |               |
| phthalate] Bromodichloromethane               | 6          | 7.55          | 75.5          | 7.63         | 7.10            | 10.4            | 22.0          |
| [Dichlorobromomethane]                        | 10.2       | 275           | 2750          | 278          | 259             | 380             | 803           |
| Bromoform [Tribromomethane]                   | 66.9       | 1060          | 10600         | 1071         | 996             | 1464            | 3098          |
| Cadmium                                       | 5          | N/A           | N/A           | N/A          | N/A             | N/A             | N/A           |
| Carbon Tetrachloride                          | 4.5        | 46            | 460           | 46.5         | 43.2            | 63.5            | 134           |
| Chlordane                                     | 0.0025     | 0.0025        | 0.025         | 0.00253      | 0.00235         | 0.00345         | 0.00730       |
| Chlorobenzene                                 | 100        | 2737          | 27370         | 2766         | 2573            | 3782            | 8001          |
| Chlorodibromomethane                          | 7.5        | 402           | 1020          | 405          | 470             | 252             | F2.4          |
| [Dibromochloromethane]                        | 7.5        | 183           | 1830          | 185          | 172             | 252             | 534           |
| Chloroform [Trichloromethane]                 | 70         | 7697          | 76970         | 7780         | 7235            | 10635           | 22501         |
| Chromium (hexavalent)                         | 62<br>2.45 | 502           | 5020          | 507          | 472             | 693             | 1467          |
| Chrysene  Cresols [Methylphenols]             | 1041       | 2.52<br>9301  | 25.2<br>93010 | 2.55<br>9401 | 2.37<br>8743    | 3.48<br>12852   | 7.36<br>27191 |
| Cyanide (free)                                | 200        | 9301<br>N/A   | 93010<br>N/A  | 9401<br>N/A  | N/A             | N/A             | 2/191<br>N/A  |
| , ,   | 0.002      | 0.002         | 0.02          | 0.00202      | 0.00188         | 0.00276         | 0.00584       |
| 4,4'-DDD<br>4,4'-DDE                          | 0.002      | 0.002         | 0.0013        | 0.00202      | 0.00188         | 0.00276         | 0.00384       |
| 4,4'-DDT                                      | 0.00013    | 0.00013       | 0.0013        | 0.000131     | 0.000122        | 0.000179        | 0.000380      |
| 2,4'-D  | 70         | 0.0004<br>N/A | N/A           | N/A          | 0.000370<br>N/A | 0.000332<br>N/A |               |
| Danitol [Fenpropathrin]                       | 262        | 473           | 4730          | 478          | 445             | 653             | N/A<br>1382   |
| 1,2-Dibromoethane [Ethylene Dibromide]        | 0.17       | 4.24          | 42.4          | 4.29         | 3.99            | 5.85            | 12.3          |
| m-Dichlorobenzene [1,3-Dichlorobenzene]       | 322        | 595           | 5950          | 601          | 559             | 822             | 1739          |
| o-Dichlorobenzene [1,2-Dichlorobenzene]       | 600        | 3299          | 32990         | 3335         | 3101            | 4558            | 9644          |
| p-Dichlorobenzene [1,4-Dichlorobenzene]       | 75         | N/A           | N/A           | N/A          | N/A             | N/A             | N/A           |
| 3,3'-Dichlorobenzidine                        | 0.79       | 2.24          | 22.4          | 2.26         | 2.11            | 3.09            | 6.54          |
| 1,2-Dichloroethane                            | 5          | 364           | 3640          | 368          | 342             | 502             | 1064          |
| 1,1-Dichloroethylene [1,1-Dichloroethene]     | 7          | 55114         | 551140        | 55708        | 51808           | 76157           | 161123        |
| Dichloromethane [Methylene Chloride]          | 5          | 13333         | 133330        | 13477        | 12533           | 18423           | 38978         |
| 1,2-Dichloropropane                           | 5          | 259           | 2590          | 262          | 243             | 357             | 757           |
| 1,3-Dichloropropene [1,3-Dichloropropylene]   | 2.8        | 119           | 1190          | 120          | 112             | 164             | 347           |
| Dicofol [Kelthane]                            | 0.30       | 0.30          | 3             | 0.303        | 0.282           | 0.414           | 0.877         |
| Dieldrin                                      | 2.0E-05    | 2.0E-05       | 2.0E-04       | 0.0000202    | 0.0000188       | 0.0000276       | 0.0000584     |
| 2,4-Dimethylphenol                            | 444        | 8436          | 84360         | 8527         | 7930            | 11657           | 24662         |
| Di-n-Butyl Phthalate                          | 88.9       | 92.4          | 924           | 93.4         | 86.9            | 127             | 270           |
| Dioxins/Furans [TCDD Equivalents]             | 7.80E-08   | 7.97E-08      | 7.97E-07      | 8.06E-08     | 7.49E-08        | 1.10E-07        | 2.32E-07      |
| Endrin  | 0.02       | 0.02          | 0.2           | 0.0202       | 0.0188          | 0.0276          | 0.0584        |
| Epichlorohydrin                               | 53.5       | 2013          | 20130         | 2035         | 1892            | 2781            | 5884          |
| Ethylbenzene                                  | 700        | 1867          | 18670         | 1887         | 1755            | 2579            | 5458          |
| Ethylene Glycol                               | 46744      | 1.68E+07      | 1.68E+08      | 16980970     | 15792302        | 23214683        | 49114058      |
| Fluoride                                      | 4000       | N/A           | N/A           | N/A          | N/A             | N/A             | N/A           |
| Heptachlor                                    | 8.0E-05    | 0.0001        | 0.001         | 0.000101     | 0.0000940       | 0.000138        | 0.000292      |
| Heptachlor Epoxide                            | 0.00029    | 0.00029       | 0.0029        | 0.000293     | 0.000273        | 0.000400        | 0.000847      |
| Hexachlorobenzene                             | 0.00068    | 0.00068       | 0.0068        | 0.000687     | 0.000639        | 0.000939        | 0.00198       |
| Hexachlorobutadiene                           | 0.21       | 0.22          | 2.2           | 0.222        | 0.207           | 0.304           | 0.643         |
| Hexachlorocyclohexane (alpha)                 | 0.0078     | 0.0084        | 0.084         | 0.00849      | 0.00790         | 0.0116          | 0.0245        |
| Hexachlorocyclohexane (beta)                  | 0.15       | 0.26          | 2.6           | 0.263        | 0.244           | 0.359           | 0.760         |
| Hexachlorocyclohexane (gamma) [Lindane]       | 0.2        | 0.341         | 3.41          | 0.345        | 0.321           | 0.471           | 0.996         |
| Hexachlorocyclopentadiene                     | 10.7       | 11.6          | 116           | 11.7         | 10.9            | 16.0            | 33.9          |

| Hexachloroethane                          | 1.84    | 2.33     | 23.3     | 2.36     | 2.19     | 3.21     | 6.81    |
|---|---------|----------|----------|----------|----------|----------|---------|
| Hexachlorophene                           | 2.05    | 2.90     | 29       | 2.93     | 2.73     | 4.00     | 8.47    |
| 4,4'-Isopropylidenediphenol               | 1092    | 15982    | 159820   | 16154    | 15023    | 22084    | 46722   |
| Lead                                      | 1.15    | 3.83     | 38.3     | 21.8     | 20.3     | 29.8     | 63.0    |
| Mercury                                   | 0.0122  | 0.0122   | 0.122    | 0.0123   | 0.0115   | 0.0168   | 0.0356  |
| Methoxychlor                              | 2.92    | 3.0      | 30       | 3.03     | 2.82     | 4.14     | 8.77    |
| Methyl Ethyl Ketone                       | 13865   | 9.92E+05 | 9.92E+06 | 1002686  | 932498   | 1370771  | 2900068 |
| Methyl tert-butyl ether [MTBE]            | 15      | 10482    | 104820   | 10595    | 9853     | 14484    | 30643   |
| Nickel                                    | 332     | 1140     | 11400    | 2795     | 2599     | 3821     | 8084    |
| Nitrate-Nitrogen (as Total Nitrogen)      | 10000   | N/A      | N/A      | N/A      | N/A      | N/A      | N/A     |
| Nitrobenzene                              | 45.7    | 1873     | 18730    | 1893     | 1761     | 2588     | 5475    |
| N-Nitrosodiethylamine                     | 0.0037  | 2.1      | 21       | 2.12     | 1.97     | 2.90     | 6.13    |
| N-Nitroso-di- <i>n</i> -Butylamine        | 0.119   | 4.2      | 42       | 4.25     | 3.95     | 5.80     | 12.2    |
| Pentachlorobenzene                        | 0.348   | 0.355    | 3.55     | 0.359    | 0.334    | 0.490    | 1.03    |
| Pentachlorophenol                         | 0.22    | 0.29     | 2.9      | 0.293    | 0.273    | 0.400    | 0.847   |
| Polychlorinated Biphenyls [PCBs]          | 6.4E-04 | 6.4E-04  | 6.40E-03 | 0.000647 | 0.000602 | 0.000884 | 0.00187 |
| Pyridine                                  | 23      | 947      | 9470     | 957      | 890      | 1308     | 2768    |
| Selenium                                  | 50      | N/A      | N/A      | N/A      | N/A      | N/A      | N/A     |
| 1,2,4,5-Tetrachlorobenzene                | 0.23    | 0.24     | 2.4      | 0.243    | 0.226    | 0.331    | 0.701   |
| 1,1,2,2-Tetrachloroethane                 | 1.64    | 26.35    | 263.5    | 26.6     | 24.8     | 36.4     | 77.0    |
| Tetrachloroethylene [Tetrachloroethylene] | 5       | 280      | 2800     | 283      | 263      | 386      | 818     |
| Thallium                                  | 0.12    | 0.23     | 2.3      | 0.232    | 0.216    | 0.317    | 0.672   |
| Toluene                                   | 1000    | N/A      | N/A      | N/A      | N/A      | N/A      | N/A     |
| Toxaphene                                 | 0.011   | 0.011    | 0.11     | 0.0111   | 0.0103   | 0.0152   | 0.0321  |
| 2,4,5-TP [Silvex]                         | 50      | 369      | 3690     | 373      | 347      | 509      | 1078    |
| 1,1,1-Trichloroethane                     | 200     | 784354   | 7843540  | 792803   | 737307   | 1083841  | 2293024 |
| 1,1,2-Trichloroethane                     | 5       | 166      | 1660     | 168      | 156      | 229      | 485     |
| Trichloroethylene [Trichloroethene]       | 5       | 71.9     | 719      | 72.7     | 67.6     | 99.3     | 210     |
| 2,4,5-Trichlorophenol                     | 1039    | 1867     | 18670    | 1887     | 1755     | 2579     | 5458    |
| TTHM [Sum of Total Trihalomethanes]       | 80      | N/A      | N/A      | N/A      | N/A      | N/A      | N/A     |
| Vinyl Chloride                            | 0.23    | 16.5     | 165      | 16.7     | 15.5     | 22.8     | 48.2    |
|   |         |          |          |          |          |          |         |

#### CALCULATE 70% AND 85% OF DAILY AVERAGE EFFLUENT LIMITATIONS:

| Aquatic Life          | 70% of<br>Daily Avg. | 85% of<br>Daily Avg. |
|-----------------------|----------------------|----------------------|
| Parameter             | (μg/L)               | (μg/L)               |
| Aldrin                | 1.77                 | 2.15                 |
| Aluminum              | 585                  | 710                  |
| Arsenic               | 231                  | 280                  |
| Cadmium               | 1.29                 | 1.57                 |
| Carbaryl              | 1.18                 | 1.43                 |
| Chlordane             | 0.00318              | 0.00386              |
| Chlorpyrifos          | 0.0326               | 0.0396               |
| Chromium (trivalent)  | 545                  | 662                  |
| Chromium (hexavalent) | 8.44                 | 10.2                 |
| Copper                | 43.4                 | 52.8                 |
| Cyanide (free)        | 8.52                 | 10.3                 |
| 4,4'-DDT              | 0.000796             | 0.000967             |
| Demeton               | 0.0796               | 0.0967               |
| Diazinon              | 0.100                | 0.121                |
| Dicofol [Kelthane]    | 15.7                 | 19.1                 |
| Dieldrin              | 0.00159              | 0.00193              |
| Diuron                | 55.7                 | 67.7                 |

| Endosulfan I (alpha)                    | 0.0446   | 0.0541   |
|---|----------|----------|
| Endosulfan II (beta)                    | 0.0446   | 0.0541   |
| Endosulfan sulfate                      | 0.0446   | 0.0541   |
| Endrin                                  | 0.00159  | 0.00193  |
| Guthion [Azinphos Methyl]               | 0.00796  | 0.00967  |
| Heptachlor                              | 0.00318  | 0.00386  |
| Hexachlorocyclohexane (gamma) [Lindane] | 0.0637   | 0.0773   |
| Lead                                    | 25.7     | 31.2     |
| Malathion                               | 0.00796  | 0.00967  |
| Mercury                                 | 1.03     | 1.25     |
| Methoxychlor                            | 0.0238   | 0.0290   |
| Mirex                                   | 0.000796 | 0.000967 |
| Nickel                                  | 192      | 233      |
| Nonylphenol                             | 5.25     | 6.38     |
| Parathion (ethyl)                       | 0.0103   | 0.0125   |
| Pentachlorophenol                       | 9.41     | 11.4     |
| Phenanthrene                            | 17.7     | 21.5     |
| Polychlorinated Biphenyls [PCBs]        | 0.0111   | 0.0135   |
| Selenium                                | 3.98     | 4.83     |
| Silver                                  | 16.4     | 19.9     |
| Toxaphene                               | 0.000159 | 0.000193 |
| Tributyltin [TBT]                       | 0.0191   | 0.0232   |
| 2,4,5 Trichlorophenol                   | 50.9     | 61.9     |
| Zinc                                    | 483      | 587      |
|   |          |          |

| Human Health   | 70% of<br>Daily Avg. | 85% of<br>Daily Avg. |
|--|----------------------|----------------------|
| Parameter  | (μg/L)               | (μg/L)               |
| Acrylonitrile  | 111                  | 135                  |
| Aldrin   | 0.0000110            | 0.0000134            |
| Anthracene   | 1273                 | 1546                 |
| Antimony   | 1035                 | 1257                 |
| Arsenic  | N/A                  | N/A                  |
| Barium   | N/A                  | N/A                  |
| Benzene  | 561                  | 682                  |
| Benzidine  | 0.103                | 0.125                |
| Benzo(a)anthracene                                       | 0.0241               | 0.0293               |
| Benzo(a)pyrene   | 0.00241              | 0.00293              |
| Bis(chloromethyl)ether                                   | 0.265                | 0.322                |
| Bis(2-chloroethyl)ether                                  | 41.4                 | 50.3                 |
| Bis(2-ethylhexyl) phthalate [Di(2-ethylhexyl) phthalate] | 7.30                 | 8.86                 |
| Bromodichloromethane [Dichlorobromomethane]              | 266                  | 323                  |
| Bromoform [Tribromomethane]                              | 1025                 | 1245                 |
| Cadmium  | N/A                  | N/A                  |
| Carbon Tetrachloride                                     | 44.4                 | 54.0                 |
| Chlordane  | 0.00241              | 0.00293              |
| Chlorobenzene  | 2647                 | 3214                 |
| Chlorodibromomethane [Dibromochloromethane]              | 177                  | 214                  |
| Chloroform [Trichloromethane]                            | 7445                 | 9040                 |
| Chromium (hexavalent)                                    | 485                  | 589                  |
| Chrysene   | 2.43                 | 2.95                 |
| Cresols [Methylphenols]                                  | 8996                 | 10924                |
| Cyanide (free)   | N/A                  | N/A                  |

| 4,4'-DDD                                    | 0.00193   | 0.00234           |
|---|-----------|-------------------|
| 4,4'-DDE                                    | 0.000133  | 0.000152          |
| 4,4'-DDT                                    | 0.000386  | 0.000469          |
| 2,4'-D                                      | N/A       | N/A               |
| Danitol [Fenpropathrin]                     | 457       | 555               |
| 1,2-Dibromoethane [Ethylene Dibromide]      | 4.10      | 4.98              |
| m-Dichlorobenzene [1,3-Dichlorobenzene]     | 575       | 698               |
| o-Dichlorobenzene [1,2-Dichlorobenzene]     | 3191      | 3874              |
| p-Dichlorobenzene [1,4-Dichlorobenzene]     | N/A       | N/A               |
| 3,3'-Dichlorobenzidine                      | 2.16      | 2.63              |
| 1,2-Dichloroethane                          | 352       | 427               |
| 1,1-Dichloroethylene [1,1-Dichloroethene]   | 53310     | 64734             |
| Dichloromethane [Methylene Chloride]        | 12896     | 15660             |
| 1,2-Dichloropropane                         | 250       | 304               |
| 1,3-Dichloropropene [1,3-Dichloropropylene] | 115       | 139               |
| Dicofol [Kelthane]                          | 0.290     | 0.352             |
| Dieldrin                                    | 0.0000193 |                   |
|   | 8159      | 0.0000234<br>9908 |
| 2,4-Dimethylphenol                          |           | 108               |
| Di-n-Butyl Phthalate                        | 89.3      |                   |
| Dioxins/Furans [TCDD Equivalents]           | 7.70E-08  | 9.36E-08          |
| Endrin                                      | 0.0193    | 0.0234            |
| Epichlorohydrin                             | 1947      | 2364              |
| Ethylbenzene                                | 1805      | 2192              |
| Ethylene Glycol                             | 16250278  | 19732481          |
| Fluoride                                    | N/A       | N/A               |
| Heptachlor                                  | 0.0000967 | 0.000117          |
| Heptachlor Epoxide                          | 0.000280  | 0.000340          |
| Hexachlorobenzene                           | 0.000657  | 0.000798          |
| Hexachlorobutadiene                         | 0.212     | 0.258             |
| Hexachlorocyclohexane (alpha)               | 0.00812   | 0.00986           |
| Hexachlorocyclohexane (beta)                | 0.251     | 0.305             |
| Hexachlorocyclohexane (gamma) [Lindane]     | 0.329     | 0.400             |
| Hexachlorocyclopentadiene                   | 11.2      | 13.6              |
| Hexachloroethane                            | 2.25      | 2.73              |
| Hexachlorophene                             | 2.80      | 3.40              |
| 4,4'-Isopropylidenediphenol                 | 15459     | 18771             |
| Lead  | 20.8      | 25.3              |
| Mercury                                     | 0.0118    | 0.0143            |
| Methoxychlor                                | 2.90      | 3.52              |
| Methyl Ethyl Ketone                         | 959540    | 1165156           |
| Methyl tert-butyl ether [MTBE]              | 10139     | 12311             |
| Nickel                                      | 2674      | 3248              |
| Nitrate-Nitrogen (as Total Nitrogen)        | N/A       | N/A               |
| Nitrobenzene                                | 1811      | 2199              |
| N-Nitrosodiethylamine                       | 2.03      | 2.46              |
| N-Nitroso-di- <i>n</i> -Butylamine          | 4.06      | 4.93              |
| Pentachlorobenzene                          | 0.343     | 0.416             |
| Pentachlorophenol                           | 0.280     | 0.340             |
| Polychlorinated Biphenyls [PCBs]            | 0.000619  | 0.000751          |
| Pyridine                                    | 916       | 1112              |
| Selenium                                    | N/A       | N/A               |
| 1,2,4,5-Tetrachlorobenzene                  | 0.232     | 0.281             |
| 1,1,2,2-Tetrachloroethane                   | 25.4      | 30.9              |
| Tetrachloroethylene [Tetrachloroethylene]   | 270       | 328               |
| Thallium                                    | 0.222     | 0.270             |

| Toluene                             | N/A    | N/A    |
|-------------------------------------|--------|--------|
| Toxaphene                           | 0.0106 | 0.0129 |
| 2,4,5-TP [Silvex]                   | 356    | 433    |
| 1,1,1-Trichloroethane               | 758688 | 921264 |
| 1,1,2-Trichloroethane               | 160    | 194    |
| Trichloroethylene [Trichloroethene] | 69.5   | 84.4   |
| 2,4,5-Trichlorophenol               | 1805   | 2192   |
| TTHM [Sum of Total Trihalomethanes] | N/A    | N/A    |
| Vinyl Chloride                      | 15.9   | 19.3   |



TPDES PERMIT NO. WQ0011041002 [For TCEQ office use only - EPA I.D. No. TX0119466]

# TEXAS COMMISSION ON ENVIRONMENTAL QUALITY P.O. Box 13087 Austin, Texas 78711-3087

This is a renewal that replaces TPDES Permit No. WQ0011041002 issued on October 6, 2020.

#### PERMIT TO DISCHARGE WASTES

under provisions of Section 402 of the Clean Water Act and Chapter 26 of the Texas Water Code

City of Kyle

whose mailing address is

100 West Center Street Kyle, Texas 78640

is authorized to treat and discharge wastes from the City of Kyle Wastewater Treatment Facility, SIC Code 4952

located at 941 New Bridge Drive in Hays County, Texas 78640

directly to Plum Creek in Segment No. 1810 of the Guadalupe River Basin

only according to effluent limitations, monitoring requirements, and other conditions set forth in this permit, as well as the rules of the Texas Commission on Environmental Quality (TCEQ), the laws of the State of Texas, and other orders of the TCEQ. The issuance of this permit does not grant to the permittee the right to use private or public property for conveyance of wastewater along the discharge route described in this permit. This includes, but is not limited to, property belonging to any individual, partnership, corporation, or other entity. Neither does this permit authorize any invasion of personal rights nor any violation of federal, state, or local laws or regulations. It is the responsibility of the permittee to acquire property rights as may be necessary to use the discharge route.

| This permit shall expire at midnight, <b>three years fro</b> | om the date of issuance. |
|--|--------------------------|
| ISSUED DATE:   |                          |
|  | For the Commission       |

#### INTERIM I EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Outfall Number 001

1. During the period beginning upon the date of issuance and lasting through the completion of expansion to the 9.0 million gallons per day (MGD) facility, the permittee is authorized to discharge subject to the following effluent limitations:

The annual average flow of effluent shall not exceed 4.5 MGD, nor shall the average discharge during any two-hour period (2-hour peak) exceed 12,500 gallons per minute (gpm).

| Effluent Characteristic                                   | Discharge Limitations |           |           |             | Min. Self-Monitoring Requirements |                         |
|---|-----------------------|-----------|-----------|-------------|-----------------------------------|-------------------------|
|   | Daily Avg             | 7-day Avg | Daily Max | Single Grab | Report Daily Avg. & Daily Max.    |                         |
|   | mg/l (lbs/day)        | mg/l      | mg/l      | mg/l        | Measurement<br>Frequency          | Sample Type             |
| Flow, MGD   | Report                | N/A       | Report    | N/A         | Continuous                        | <b>Totalizing Meter</b> |
| Carbonaceous Biochemical<br>Oxygen Demand (5-day)         | 10 (375)              | 15        | 25        | 35          | Two/week                          | Composite               |
| Total Suspended Solids                                    | 15 (563)              | 25        | 40        | 60          | Two/week                          | Composite               |
| Ammonia Nitrogen  | 2 (75)                | 5         | 10        | 15          | Two/week                          | Composite               |
| E. coli, colony-forming units or most probable number per | 126                   | N/A       | 399       | N/A         | Daily                             | Grab                    |

- 2. The permittee shall utilize an Ultraviolet Light (UV) system for disinfection purposes. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.
- 3. The pH shall not be less than 6.5 standard units nor greater than 9.0 standard units and shall be monitored once per week by grab sample.
- 4. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.
- 5. Effluent monitoring samples shall be taken at the following location(s): Following the final treatment unit.
- 6. The effluent shall contain a minimum dissolved oxygen of 5.0 mg/l and shall be monitored twice per week by grab sample.
- 7. The annual average flow and maximum 2-hour peak flow shall be reported monthly.

#### INTERIM II EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Outfall Number 001

1. During the period beginning upon the date of completion of expansion to the 9.0 million gallons per day (MGD) facility and lasting through the date of completion of expansion to the 12.0 MGD facility, the permittee is authorized to discharge subject to the following effluent limitations:

The annual average flow of effluent shall not exceed 9.0 MGD, nor shall the average discharge during any two-hour period (2-hour peak) exceed 25,000 gallons per minute (gpm).

| Effluent Characteristic  |                             | Discharge Limitations |                   |                     | Min. Self-Monitoring Requirements        |                                  |
|--|-----------------------------|-----------------------|-------------------|---------------------|--|----------------------------------|
|  | Daily Avg<br>mg/l (lbs/day) | 7-day Avg<br>mg/l     | Daily Max<br>mg/l | Single Grab<br>mg/l | Report Daily<br>Measurement<br>Frequency | Avg. & Daily Max.<br>Sample Type |
| Flow, MGD  | Report                      | N/A                   | Report            | N/A                 | Continuous                               | <b>Totalizing Meter</b>          |
| Carbonaceous Biochemical<br>Oxygen Demand (5-day)                        | 7 (525)                     | 12                    | 22                | 32                  | Five/Week                                | Composite                        |
| <b>Total Suspended Solids</b>  | 15 (1,126)                  | 25                    | 40                | 60                  | Five/Week                                | Composite                        |
| Ammonia Nitrogen   | 2 (150)                     | 5                     | 10                | 15                  | Five/Week                                | Composite                        |
| Total Phosphorus   | 0.5 (38)                    | 1                     | 2                 | 3                   | Five/Week                                | Composite                        |
| <i>E. coli</i> , colony-forming units or most probable number per 100 ml | 126                         | N/A                   | 399               | N/A                 | Daily                                    | Grab                             |

- 2. The permittee shall utilize an Ultraviolet Light (UV) system for disinfection purposes. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.
- 3. The pH shall not be less than 6.5 standard units nor greater than 9.0 standard units and shall be monitored five times per week by grab sample.
- 4. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.
- 5. Effluent monitoring samples shall be taken at the following location(s): Following the final treatment unit.
- 6. The effluent shall contain a minimum dissolved oxygen of 5.0 mg/l and shall be monitored once per day by grab sample.
- 7. The annual average flow and maximum 2-hour peak flow shall be reported monthly.

#### FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Outfall Number 001

1. During the period beginning upon the completion of expansion to the 12.0 million gallons per day (MGD) facility and lasting through the date of expiration, the permittee is authorized to discharge subject to the following effluent limitations:

The annual average flow of effluent shall not exceed 12.0 MGD, nor shall the average discharge during any two-hour period (2-hour peak) exceed 39,344 gallons per minute (gpm).

| Effluent Characteristic  | Discharge Limitations       |                   |                   |                     | Min. Self-Monitoring Requirements        |                                    |
|--|-----------------------------|-------------------|-------------------|---------------------|--|------------------------------------|
|  | Daily Avg<br>mg/l (lbs/day) | 7-day Avg<br>mg/l | Daily Max<br>mg/l | Single Grab<br>mg/l | Report Daily<br>Measurement<br>Frequency | y Avg. & Daily Max.<br>Sample Type |
| Flow, MGD  | Report                      | N/A               | Report            | N/A                 | Continuous                               | Totalizing Meter                   |
| Carbonaceous Biochemical<br>Oxygen Demand (5-day)                        | 5 (500)                     | 10                | 20                | 30                  | One/day                                  | Composite                          |
| <b>Total Suspended Solids</b>  | 15 (1,501)                  | 25                | 40                | 60                  | One/day                                  | Composite                          |
| Ammonia Nitrogen   | 2 (200)                     | 5                 | 10                | 15                  | One/day                                  | Composite                          |
| Total Phosphorus   | 0.5 (50)                    | 1                 | 2                 | 3                   | One/day                                  | Composite                          |
| <i>E. coli</i> , colony-forming units or most probable number per 100 ml | 126                         | N/A               | 399               | N/A                 | Daily                                    | Grab                               |

- 2. The permittee shall utilize an Ultraviolet Light (UV) system for disinfection purposes. An equivalent method of disinfection may be substituted only with prior approval of the Executive Director.
- 3. The pH shall not be less than 6.5 standard units nor greater than 9.0 standard units and shall be monitored once per day by grab sample.
- 4. There shall be no discharge of floating solids or visible foam in other than trace amounts and no discharge of visible oil.
- 5. Effluent monitoring samples shall be taken at the following location(s): Following the final treatment unit.
- 6. The effluent shall contain a minimum dissolved oxygen of 5.0 mg/l and shall be monitored once per day by grab sample.
- 7. The annual average flow and maximum 2-hour peak flow shall be reported monthly.

Page 2b

#### **DEFINITIONS AND STANDARD PERMIT CONDITIONS**

As required by Title 30 Texas Administrative Code (TAC) Chapter 305, certain regulations appear as standard conditions in waste discharge permits. 30 TAC § 305.121 - 305.129 (relating to Permit Characteristics and Conditions) as promulgated under the Texas Water Code (TWC) §§ 5.103 and 5.105, and the Texas Health and Safety Code (THSC) §§ 361.017 and 361.024(a), establish the characteristics and standards for waste discharge permits, including sewage sludge, and those sections of 40 Code of Federal Regulations (CFR) Part 122 adopted by reference by the Commission. The following text includes these conditions and incorporates them into this permit. All definitions in TWC § 26.001 and 30 TAC Chapter 305 shall apply to this permit and are incorporated by reference. Some specific definitions of words or phrases used in this permit are as follows:

#### 1. Flow Measurements

- a. Annual average flow the arithmetic average of all daily flow determinations taken within the preceding 12 consecutive calendar months. The annual average flow determination shall consist of daily flow volume determinations made by a totalizing meter, charted on a chart recorder and limited to major domestic wastewater discharge facilities with one million gallons per day or greater permitted flow.
- b. Daily average flow the arithmetic average of all determinations of the daily flow within a period of one calendar month. The daily average flow determination shall consist of determinations made on at least four separate days. If instantaneous measurements are used to determine the daily flow, the determination shall be the arithmetic average of all instantaneous measurements taken during that month. Daily average flow determination for intermittent discharges shall consist of a minimum of three flow determinations on days of discharge.
- c. Daily maximum flow the highest total flow for any 24-hour period in a calendar month.
- d. Instantaneous flow the measured flow during the minimum time required to interpret the flow measuring device.
- e. 2-hour peak flow (domestic wastewater treatment plants) the maximum flow sustained for a two-hour period during the period of daily discharge. The average of multiple measurements of instantaneous maximum flow within a two-hour period may be used to calculate the 2-hour peak flow.
- f. Maximum 2-hour peak flow (domestic wastewater treatment plants) the highest 2-hour peak flow for any 24-hour period in a calendar month.

#### 2. Concentration Measurements

- a. Daily average concentration the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar month, consisting of at least four separate representative measurements.
  - i. For domestic wastewater treatment plants When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values in the previous four consecutive month period consisting of at least four measurements shall be utilized as the daily average concentration.

- ii. For all other wastewater treatment plants When four samples are not available in a calendar month, the arithmetic average (weighted by flow) of all values taken during the month shall be utilized as the daily average concentration.
- b. 7-day average concentration the arithmetic average of all effluent samples, composite or grab as required by this permit, within a period of one calendar week, Sunday through Saturday.
- c. Daily maximum concentration the maximum concentration measured on a single day, by the sample type specified in the permit, within a period of one calendar month.
- d. Daily discharge the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in terms of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the sampling day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the average measurement of the pollutant over the sampling day.
  - The daily discharge determination of concentration made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the daily discharge determination of concentration shall be the arithmetic average (weighted by flow value) of all samples collected during that day.
- e. Bacteria concentration (*E. coli* or Enterococci) Colony Forming Units (CFU) or Most Probable Number (MPN) of bacteria per 100 milliliters effluent. The daily average bacteria concentration is a geometric mean of the values for the effluent samples collected in a calendar month. The geometric mean shall be determined by calculating the nth root of the product of all measurements made in a calendar month, where n equals the number of measurements made; or, computed as the antilogarithm of the arithmetic mean of the logarithms of all measurements made in a calendar month. For any measurement of bacteria equaling zero, a substituted value of one shall be made for input into either computation method. If specified, the 7-day average for bacteria is the geometric mean of the values for all effluent samples collected during a calendar week.
- f. Daily average loading (lbs/day) the arithmetic average of all daily discharge loading calculations during a period of one calendar month. These calculations must be made for each day of the month that a parameter is analyzed. The daily discharge, in terms of mass (lbs/day), is calculated as (Flow, MGD x Concentration, mg/l x 8.34).
- g. Daily maximum loading (lbs/day) the highest daily discharge, in terms of mass (lbs/day), within a period of one calendar month.

#### 3. Sample Type

a. Composite sample - For domestic wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC § 319.9 (a). For industrial wastewater, a composite sample is a sample made up of a minimum of three effluent portions collected in a continuous 24-hour period or during the period of daily discharge if less than 24 hours, and combined in volumes proportional to flow, and collected at the intervals required by 30 TAC § 319.9 (b).

- b. Grab sample an individual sample collected in less than 15 minutes.
- 4. Treatment Facility (facility) wastewater facilities used in the conveyance, storage, treatment, recycling, reclamation and/or disposal of domestic sewage, industrial wastes, agricultural wastes, recreational wastes, or other wastes including sludge handling or disposal facilities under the jurisdiction of the Commission.
- 5. The term "sewage sludge" is defined as solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in 30 TAC Chapter 312. This includes the solids that have not been classified as hazardous waste separated from wastewater by unit processes.
- 6. The term "biosolids" is defined as sewage sludge that has been tested or processed to meet Class A, Class AB, or Class B pathogen standards in 30 TAC Chapter 312 for beneficial use.
- 7. Bypass the intentional diversion of a waste stream from any portion of a treatment facility.

#### MONITORING AND REPORTING REQUIREMENTS

#### 1. Self-Reporting

Monitoring results shall be provided at the intervals specified in the permit. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall conduct effluent sampling and reporting in accordance with 30 TAC §§ 319.4 - 319.12. Unless otherwise specified, effluent monitoring data shall be submitted each month, to the Compliance Monitoring Team of the Enforcement Division (MC 224), by the 20th day of the following month for each discharge which is described by this permit whether or not a discharge is made for that month. Monitoring results must be submitted online using the NetDMR reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. Monitoring results must be signed and certified as required by Monitoring and Reporting Requirements No. 10.

As provided by state law, the permittee is subject to administrative, civil and criminal penalties, as applicable, for negligently or knowingly violating the Clean Water Act (CWA); TWC §§ 26, 27, and 28; and THSC § 361, including but not limited to knowingly making any false statement, representation, or certification on any report, record, or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance, or falsifying, tampering with or knowingly rendering inaccurate any monitoring device or method required by this permit or violating any other requirement imposed by state or federal regulations.

#### 2. Test Procedures

- a. Unless otherwise specified in this permit, test procedures for the analysis of pollutants shall comply with procedures specified in 30 TAC §§ 319.11 319.12. Measurements, tests, and calculations shall be accurately accomplished in a representative manner.
- b. All laboratory tests submitted to demonstrate compliance with this permit must meet the requirements of 30 TAC § 25, Environmental Testing Laboratory Accreditation and Certification.

#### 3. Records of Results

a. Monitoring samples and measurements shall be taken at times and in a manner so as to be representative of the monitored activity.

- b. Except for records of monitoring information required by this permit related to the permittee's sewage sludge or biosolids use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503), monitoring and reporting records, including strip charts and records of calibration and maintenance, copies of all records required by this permit, records of all data used to complete the application for this permit, and the certification required by 40 CFR § 264.73(b)(9) shall be retained at the facility site, or shall be readily available for review by a TCEQ representative for a period of three years from the date of the record or sample, measurement, report, application or certification. This period shall be extended at the request of the Executive Director.
- c. Records of monitoring activities shall include the following:
  - i. date, time and place of sample or measurement;
  - ii. identity of individual who collected the sample or made the measurement.
  - iii. date and time of analysis;
  - iv. identity of the individual and laboratory who performed the analysis;
  - v. the technique or method of analysis; and
  - vi. the results of the analysis or measurement and quality assurance/quality control records.

The period during which records are required to be kept shall be automatically extended to the date of the final disposition of any administrative or judicial enforcement action that may be instituted against the permittee.

#### 4. Additional Monitoring by Permittee

If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit using approved analytical methods as specified above, all results of such monitoring shall be included in the calculation and reporting of the values submitted on the approved self-report form. Increased frequency of sampling shall be indicated on the self-report form.

#### 5. Calibration of Instruments

All automatic flow measuring or recording devices and all totalizing meters for measuring flows shall be accurately calibrated by a trained person at plant start-up and as often thereafter as necessary to ensure accuracy, but not less often than annually unless authorized by the Executive Director for a longer period. Such person shall verify in writing that the device is operating properly and giving accurate results. Copies of the verification shall be retained at the facility site and/or shall be readily available for review by a TCEQ representative for a period of three years.

#### 6. Compliance Schedule Reports

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of the permit shall be submitted no later than 14 days following each schedule date to the Regional Office and the Compliance Monitoring Team of the Enforcement Division (MC 224).

#### 7. Noncompliance Notification

- a. In accordance with 30 TAC § 305.125(9) any noncompliance which may endanger human health or safety, or the environment shall be reported by the permittee to the TCEQ. Except as allowed by 30 TAC § 305.132, report of such information shall be provided orally or by facsimile transmission (FAX) to the Regional Office within 24 hours of becoming aware of the noncompliance. A written submission of such information shall also be provided by the permittee to the Regional Office and the Compliance Monitoring Team of the Enforcement Division (MC 224) within five working days of becoming aware of the noncompliance. For Publicly Owned Treatment Works (POTWs), effective December 21, 2025, the permittee must submit the written report for unauthorized discharges and unanticipated bypasses that exceed any effluent limit in the permit using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver. The written submission shall contain a description of the noncompliance and its cause; the potential danger to human health or safety, or the environment; the period of noncompliance, including exact dates and times; if the noncompliance has not been corrected, the time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance, and to mitigate its adverse effects.
- b. The following violations shall be reported under Monitoring and Reporting Requirement 7.a.:
  - i. Unauthorized discharges as defined in Permit Condition 2(g).
  - ii. Any unanticipated bypass that exceeds any effluent limitation in the permit.
  - iii. Violation of a permitted maximum daily discharge limitation for pollutants listed specifically in the Other Requirements section of an Industrial TPDES permit.
- c. In addition to the above, any effluent violation which deviates from the permitted effluent limitation by more than 40% shall be reported by the permittee in writing to the Regional Office and the Compliance Monitoring Team of the Enforcement Division (MC 224) within 5 working days of becoming aware of the noncompliance.
- d. Any noncompliance other than that specified in this section, or any required information not submitted or submitted incorrectly, shall be reported to the Compliance Monitoring Team of the Enforcement Division (MC 224) as promptly as possible. For effluent limitation violations, noncompliances shall be reported on the approved self-report form.
- 8. In accordance with the procedures described in 30 TAC §§ 35.301 35.303 (relating to Water Quality Emergency and Temporary Orders) if the permittee knows in advance of the need for a bypass, it shall submit prior notice by applying for such authorization.
- 9. Changes in Discharges of Toxic Substances

All existing manufacturing, commercial, mining, and silvicultural permittees shall notify the Regional Office, orally or by facsimile transmission within 24 hours, and both the Regional Office and the Compliance Monitoring Team of the Enforcement Division (MC 224) in writing within five (5) working days, after becoming aware of or having reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant listed at 40 CFR Part 122, Appendix D, Tables II and III (excluding Total Phenols) which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
  - i. One hundred micrograms per liter (100  $\mu$ g/L);
  - ii. Two hundred micrograms per liter (200  $\mu$ g/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500  $\mu$ g/L) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
  - iii. Five (5) times the maximum concentration value reported for that pollutant in the permit application; or
  - iv. The level established by the TCEQ.
- b. That any activity has occurred or will occur which would result in any discharge, on a nonroutine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
  - i. Five hundred micrograms per liter (500  $\mu$ g/L);
  - ii. One milligram per liter (1 mg/L) for antimony;
  - iii. Ten (10) times the maximum concentration value reported for that pollutant in the permit application; or
  - iv. The level established by the TCEQ.

#### 10. Signatories to Reports

All reports and other information requested by the Executive Director shall be signed by the person and in the manner required by 30 TAC § 305.128 (relating to Signatories to Reports).

- 11. All POTWs must provide adequate notice to the Executive Director of the following:
  - a. Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to CWA § 301 or § 306 if it were directly discharging those pollutants;
  - b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit; and
  - c. For the purpose of this paragraph, adequate notice shall include information on:
    - i. The quality and quantity of effluent introduced into the POTW; and
    - ii. Any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.

#### PERMIT CONDITIONS

#### 1. General

- a. When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in an application or in any report to the Executive Director, it shall promptly submit such facts or information.
- b. This permit is granted on the basis of the information supplied and representations made by the permittee during action on an application, and relying upon the accuracy and completeness of that information and those representations. After notice and opportunity for a hearing, this permit may be modified, suspended, or revoked, in whole or in part, in accordance with 30 TAC Chapter 305, Subchapter D, during its term for good cause including, but not limited to, the following:
  - i. Violation of any terms or conditions of this permit;
  - ii. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
  - iii. A change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge.
- c. The permittee shall furnish to the Executive Director, upon request and within a reasonable time, any information to determine whether cause exists for amending, revoking, suspending or terminating the permit. The permittee shall also furnish to the Executive Director, upon request, copies of records required to be kept by the permit.

#### 2. Compliance

- a. Acceptance of the permit by the person to whom it is issued constitutes acknowledgment and agreement that such person will comply with all the terms and conditions embodied in the permit, and the rules and other orders of the Commission.
- b. The permittee has a duty to comply with all conditions of the permit. Failure to comply with any permit condition constitutes a violation of the permit and the Texas Water Code or the Texas Health and Safety Code, and is grounds for enforcement action, for permit amendment, revocation, or suspension, or for denial of a permit renewal application or an application for a permit for another facility.
- c. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit.
- d. The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal or other permit violation that has a reasonable likelihood of adversely affecting human health or the environment.
- e. Authorization from the Commission is required before beginning any change in the permitted facility or activity that may result in noncompliance with any permit requirements.

- f. A permit may be amended, suspended and reissued, or revoked for cause in accordance with 30 TAC §§ 305.62 and 305.66 and TWC§ 7.302. The filing of a request by the permittee for a permit amendment, suspension and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
- g. There shall be no unauthorized discharge of wastewater or any other waste. For the purpose of this permit, an unauthorized discharge is considered to be any discharge of wastewater into or adjacent to water in the state at any location not permitted as an outfall or otherwise defined in the Other Requirements section of this permit.
- h. In accordance with 30 TAC § 305.535(a), the permittee may allow any bypass to occur from a TPDES permitted facility which does not cause permitted effluent limitations to be exceeded or an unauthorized discharge to occur, but only if the bypass is also for essential maintenance to assure efficient operation.
- i. The permittee is subject to administrative, civil, and criminal penalties, as applicable, under TWC §§ 7.051 7.075 (relating to Administrative Penalties), 7.101 7.111 (relating to Civil Penalties), and 7.141 7.202 (relating to Criminal Offenses and Penalties) for violations including, but not limited to, negligently or knowingly violating the federal CWA §§ 301, 302, 306, 307, 308, 318, or 405, or any condition or limitation implementing any sections in a permit issued under the CWA § 402, or any requirement imposed in a pretreatment program approved under the CWA §§ 402 (a)(3) or 402 (b)(8).

#### 3. Inspections and Entry

- a. Inspection and entry shall be allowed as prescribed in the TWC Chapters 26, 27, and 28, and THSC § 361.
- b. The members of the Commission and employees and agents of the Commission are entitled to enter any public or private property at any reasonable time for the purpose of inspecting and investigating conditions relating to the quality of water in the state or the compliance with any rule, regulation, permit or other order of the Commission. Members, employees, or agents of the Commission and Commission contractors are entitled to enter public or private property at any reasonable time to investigate or monitor or, if the responsible party is not responsive or there is an immediate danger to public health or the environment, to remove or remediate a condition related to the quality of water in the state. Members, employees, Commission contractors, or agents acting under this authority who enter private property shall observe the establishment's rules and regulations concerning safety, internal security, and fire protection, and if the property has management in residence, shall notify management or the person then in charge of his presence and shall exhibit proper credentials. If any member, employee, Commission contractor, or agent is refused the right to enter in or on public or private property under this authority, the Executive Director may invoke the remedies authorized in TWC § 7.002. The statement above, that Commission entry shall occur in accordance with an establishment's rules and regulations concerning safety, internal security, and fire protection, is not grounds for denial or restriction of entry to any part of the facility, but merely describes the Commission's duty to observe appropriate rules and regulations during an inspection.

#### 4. Permit Amendment and/or Renewal

- a. The permittee shall give notice to the Executive Director as soon as possible of any planned physical alterations or additions to the permitted facility if such alterations or additions would require a permit amendment or result in a violation of permit requirements. Notice shall also be required under this paragraph when:
  - The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in accordance with 30 TAC § 305.534 (relating to New Sources and New Dischargers); or
  - ii. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in the permit, nor to notification requirements in Monitoring and Reporting Requirements No. 9; or
  - iii. The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
- b. Prior to any facility modifications, additions, or expansions that will increase the plant capacity beyond the permitted flow, the permittee must apply for and obtain proper authorization from the Commission before commencing construction.
- c. The permittee must apply for an amendment or renewal at least 180 days prior to expiration of the existing permit in order to continue a permitted activity after the expiration date of the permit. If an application is submitted prior to the expiration date of the permit, the existing permit shall remain in effect until the application is approved, denied, or returned. If the application is returned or denied, authorization to continue such activity shall terminate upon the effective date of the action. If an application is not submitted prior to the expiration date of the permit, the permit shall expire and authorization to continue such activity shall terminate.
- d. Prior to accepting or generating wastes which are not described in the permit application or which would result in a significant change in the quantity or quality of the existing discharge, the permittee must report the proposed changes to the Commission. The permittee must apply for a permit amendment reflecting any necessary changes in permit conditions, including effluent limitations for pollutants not identified and limited by this permit.
- e. In accordance with the TWC § 26.029(b), after a public hearing, notice of which shall be given to the permittee, the Commission may require the permittee, from time to time, for good cause, in accordance with applicable laws, to conform to new or additional conditions.
- f. If any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under CWA § 307(a) for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitation on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standard or

prohibition. The permittee shall comply with effluent standards or prohibitions established under CWA § 307(a) for toxic pollutants within the time provided in the regulations that established those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

#### 5. Permit Transfer

- a. Prior to any transfer of this permit, Commission approval must be obtained. The Commission shall be notified in writing of any change in control or ownership of facilities authorized by this permit. Such notification should be sent to the Applications Review and Processing Team (MC 148) of the Water Quality Division.
- b. A permit may be transferred only according to the provisions of 30 TAC § 305.64 (relating to Transfer of Permits) and 30 TAC § 50.133 (relating to Executive Director Action on Application or WQMP update).

#### 6. Relationship to Hazardous Waste Activities

This permit does not authorize any activity of hazardous waste storage, processing, or disposal that requires a permit or other authorization pursuant to the Texas Health and Safety Code.

#### 7. Relationship to Water Rights

Disposal of treated effluent by any means other than discharge directly to water in the state must be specifically authorized in this permit and may require a permit pursuant to TWC Chapter 11.

#### 8. Property Rights

A permit does not convey any property rights of any sort, or any exclusive privilege.

#### 9. Permit Enforceability

The conditions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstances, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

#### 10. Relationship to Permit Application

The application pursuant to which the permit has been issued is incorporated herein; provided, however, that in the event of a conflict between the provisions of this permit and the application, the provisions of the permit shall control.

#### 11. Notice of Bankruptcy

- a. Each permittee shall notify the Executive Director, in writing, immediately following the filing of a voluntary or involuntary petition for bankruptcy under any chapter of Title 11 (Bankruptcy) of the United States Code (11 USC) by or against:
  - i. the permittee;
  - ii. an entity (as that term is defined in 11 USC, § 101(14)) controlling the permittee or listing the permit or permittee as property of the estate; or

- iii. an affiliate (as that term is defined in 11 USC, § 101(2)) of the permittee.
- b. This notification must indicate:
  - i. the name of the permittee;
  - ii. the permit number(s);
  - iii. the bankruptcy court in which the petition for bankruptcy was filed; and
  - iv. the date of filing of the petition.

#### **OPERATIONAL REQUIREMENTS**

- 1. The permittee shall at all times ensure that the facility and all of its systems of collection, treatment, and disposal are properly operated and maintained. This includes, but is not limited to, the regular, periodic examination of wastewater solids within the treatment plant by the operator in order to maintain an appropriate quantity and quality of solids inventory as described in the various operator training manuals and according to accepted industry standards for process control. Process control, maintenance, and operations records shall be retained at the facility site, or shall be readily available for review by a TCEQ representative, for a period of three years.
- 2. Upon request by the Executive Director, the permittee shall take appropriate samples and provide proper analysis in order to demonstrate compliance with Commission rules. Unless otherwise specified in this permit or otherwise ordered by the Commission, the permittee shall comply with all applicable provisions of 30 TAC Chapter 312 concerning sewage sludge or biosolids use and disposal and 30 TAC §§ 319.21 319.29 concerning the discharge of certain hazardous metals.
- 3. Domestic wastewater treatment facilities shall comply with the following provisions:
  - a. The permittee shall notify the Municipal Permits Team, Wastewater Permitting Section (MC 148) of the Water Quality Division, in writing, of any facility expansion at least 90 days prior to conducting such activity.
  - b. The permittee shall submit a closure plan for review and approval to the Municipal Permits Team, Wastewater Permitting Section (MC 148) of the Water Quality Division, for any closure activity at least 90 days prior to conducting such activity. Closure is the act of permanently taking a waste management unit or treatment facility out of service and includes the permanent removal from service of any pit, tank, pond, lagoon, surface impoundment and/or other treatment unit regulated by this permit.
- 4. The permittee is responsible for installing prior to plant start-up, and subsequently maintaining, adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failures by means of alternate power sources, standby generators, and/or retention of inadequately treated wastewater.
- 5. Unless otherwise specified, the permittee shall provide a readily accessible sampling point and, where applicable, an effluent flow measuring device or other acceptable means by which effluent flow may be determined.

6. The permittee shall remit an annual water quality fee to the Commission as required by 30 TAC Chapter 21. Failure to pay the fee may result in revocation of this permit under TWC § 7.302(b)(6).

#### 7. Documentation

For all written notifications to the Commission required of the permittee by this permit, the permittee shall keep and make available a copy of each such notification under the same conditions as self-monitoring data are required to be kept and made available. Except for information required for TPDES permit applications, effluent data, including effluent data in permits, draft permits and permit applications, and other information specified as not confidential in 30 TAC §§ 1.5(d), any information submitted pursuant to this permit may be claimed as confidential by the submitter. Any such claim must be asserted in the manner prescribed in the application form or by stamping the words confidential business information on each page containing such information. If no claim is made at the time of submission, information may be made available to the public without further notice. If the Commission or Executive Director agrees with the designation of confidentiality, the TCEQ will not provide the information for public inspection unless required by the Texas Attorney General or a court pursuant to an open records request. If the Executive Director does not agree with the designation of confidentiality, the person submitting the information will be notified.

- 8. Facilities that generate domestic wastewater shall comply with the following provisions; domestic wastewater treatment facilities at permitted industrial sites are excluded.
  - a. Whenever flow measurements for any domestic sewage treatment facility reach 75% of the permitted daily average or annual average flow for three consecutive months, the permittee must initiate engineering and financial planning for expansion and/or upgrading of the domestic wastewater treatment and/or collection facilities. Whenever the flow reaches 90% of the permitted daily average or annual average flow for three consecutive months, the permittee shall obtain necessary authorization from the Commission to commence construction of the necessary additional treatment and/or collection facilities. In the case of a domestic wastewater treatment facility which reaches 75% of the permitted daily average or annual average flow for three consecutive months, and the planned population to be served or the quantity of waste produced is not expected to exceed the design limitations of the treatment facility, the permittee shall submit an engineering report supporting this claim to the Executive Director of the Commission.

If in the judgment of the Executive Director the population to be served will not cause permit noncompliance, then the requirement of this section may be waived. To be effective, any waiver must be in writing and signed by the Director of the Enforcement Division (MC 219) of the Commission, and such waiver of these requirements will be reviewed upon expiration of the existing permit; however, any such waiver shall not be interpreted as condoning or excusing any violation of any permit parameter.

b. The plans and specifications for domestic sewage collection and treatment works associated with any domestic permit must be approved by the Commission and failure to secure approval before commencing construction of such works or making a discharge is a violation of this permit and each day is an additional violation until approval has been secured.

- c. Permits for domestic wastewater treatment plants are granted subject to the policy of the Commission to encourage the development of area-wide waste collection, treatment, and disposal systems. The Commission reserves the right to amend any domestic wastewater permit in accordance with applicable procedural requirements to require the system covered by this permit to be integrated into an area-wide system, should such be developed; to require the delivery of the wastes authorized to be collected in, treated by or discharged from said system, to such area-wide system; or to amend this permit in any other particular to effectuate the Commission's policy. Such amendments may be made when the changes required are advisable for water quality control purposes and are feasible on the basis of waste treatment technology, engineering, financial, and related considerations existing at the time the changes are required, exclusive of the loss of investment in or revenues from any then existing or proposed waste collection, treatment or disposal system.
- 9. Domestic wastewater treatment plants shall be operated and maintained by sewage plant operators holding a valid certificate of competency at the required level as defined in 30 TAC Chapter 30.
- 10. For Publicly Owned Treatment Works (POTWs), the 30-day average (or monthly average) percent removal for BOD and TSS shall not be less than 85%, unless otherwise authorized by this permit.
- 11. Facilities that generate industrial solid waste as defined in 30 TAC § 335.1 shall comply with these provisions:
  - a. Any solid waste, as defined in 30 TAC § 335.1 (including but not limited to such wastes as garbage, refuse, sludge from a waste treatment, water supply treatment plant or air pollution control facility, discarded materials, discarded materials to be recycled, whether the waste is solid, liquid, or semisolid), generated by the permittee during the management and treatment of wastewater, must be managed in accordance with all applicable provisions of 30 TAC Chapter 335, relating to Industrial Solid Waste Management.
  - b. Industrial wastewater that is being collected, accumulated, stored, or processed before discharge through any final discharge outfall, specified by this permit, is considered to be industrial solid waste until the wastewater passes through the actual point source discharge and must be managed in accordance with all applicable provisions of 30 TAC Chapter 335.
  - c. The permittee shall provide written notification, pursuant to the requirements of 30 TAC § 335.8(b)(1), to the Corrective Action Section (MC 127) of the Remediation Division informing the Commission of any closure activity involving an Industrial Solid Waste Management Unit, at least 90 days prior to conducting such an activity.
  - d. Construction of any industrial solid waste management unit requires the prior written notification of the proposed activity to the Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division. No person shall dispose of industrial solid waste, including sludge or other solids from wastewater treatment processes, prior to fulfilling the deed recordation requirements of 30 TAC § 335.5.
  - e. The term "industrial solid waste management unit" means a landfill, surface impoundment, waste-pile, industrial furnace, incinerator, cement kiln, injection well,

container, drum, salt dome waste containment cavern, or any other structure vessel, appurtenance, or other improvement on land used to manage industrial solid waste.

- f. The permittee shall keep management records for all sludge (or other waste) removed from any wastewater treatment process. These records shall fulfill all applicable requirements of 30 TAC § 335 and must include the following, as it pertains to wastewater treatment and discharge:
  - i. Volume of waste and date(s) generated from treatment process;
  - ii. Volume of waste disposed of on-site or shipped off-site;
  - iii. Date(s) of disposal;
  - iv. Identity of hauler or transporter;
  - v. Location of disposal site; and
  - vi. Method of final disposal.

The above records shall be maintained on a monthly basis. The records shall be retained at the facility site, or shall be readily available for review by authorized representatives of the TCEQ for at least five years.

12. For industrial facilities to which the requirements of 30 TAC § 335 do not apply, sludge and solid wastes, including tank cleaning and contaminated solids for disposal, shall be disposed of in accordance with THSC § 361.

TCEO Revision 06/2020

#### **SLUDGE PROVISIONS**

The permittee is authorized to dispose of sludge only at a Texas Commission on Environmental Quality (TCEQ) authorized land application site, co-disposal landfill, wastewater treatment facility, or facility that further processes sludge. The disposal of sludge or biosolids by land application on property owned, leased or under the direct control of the permittee is a violation of the permit unless the site is authorized with the TCEQ. This provision does not authorize Distribution and Marketing of Class A or Class AB Biosolids. This provision does not authorize the permittee to land apply biosolids on property owned, leased or under the direct control of the permittee.

### SECTION I. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE OR BIOSOLIDS LAND APPLICATION

#### A. General Requirements

- 1. The permittee shall handle and dispose of sewage sludge or biosolids in accordance with 30 TAC § 312 and all other applicable state and federal regulations in a manner that protects public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present in the sludge or biosolids.
- 2. In all cases, if the person (permit holder) who prepares the sewage sludge supplies the sewage sludge to another person for land application use or to the owner or lease holder of the land, the permit holder shall provide necessary information to the parties who receive the sludge to assure compliance with these regulations.
- 3. The land application of processed or unprocessed chemical toilet waste, grease trap waste, grit trap waste, milk solids, or similar non-hazardous municipal or industrial solid wastes, or any of the wastes listed in this provision combined with biosolids, WTP residuals or domestic septage is prohibited unless the grease trap waste is added at a fats, oil and grease (FOG) receiving facility as part of an anaerobic digestion process.

#### **B.** Testing Requirements

1. Sewage sludge or biosolids shall be tested annually in accordance with the method specified in both 40 CFR Part 261, Appendix II and 40 CFR Part 268, Appendix I [Toxicity Characteristic Leaching Procedure (TCLP)] or other method that receives the prior approval of the TCEQ for the contaminants listed in 40 CFR Part 261.24, Table 1. Sewage sludge or biosolids failing this test shall be managed according to RCRA standards for generators of hazardous waste, and the waste's disposition must be in accordance with all applicable requirements for hazardous waste processing, storage, or disposal. Following failure of any TCLP test, the management or disposal of sewage sludge or biosolids at a facility other than an authorized hazardous waste processing, storage, or disposal facility shall be prohibited until such time as the permittee can demonstrate the sewage sludge or biosolids no longer exhibits the hazardous waste toxicity characteristics (as demonstrated by the results of the TCLP tests). A written report shall be provided to both the TCEQ Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division and the Regional Director (MC Region 11) within seven (7) days after failing the TCLP Test.

The report shall contain test results, certification that unauthorized waste management has stopped and a summary of alternative disposal plans that comply with RCRA standards for the management of hazardous waste. The report shall be addressed to: Director, Permitting and Registration Support Division (MC 129), Texas Commission on Environmental Quality, P.O. Box 13087, Austin, Texas 78711-3087. In addition, the permittee shall prepare an annual report on the results of all sludge toxicity testing. This annual report shall be submitted to the TCEQ Regional Office (MC Region 11) and the Compliance Monitoring Team (MC 224) of the Enforcement Division by September 30<sup>th</sup> of each year. Effective December 21, 2025, the permittee must submit this annual report using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver.

2. Biosolids shall not be applied to the land if the concentration of the pollutants exceeds the pollutant concentration criteria in Table 1. The frequency of testing for pollutants in Table 1 is found in Section I.C. of this permit.

TABLE 1

| <u>Pollutant</u> | Ceiling Concentration      |
|------------------|----------------------------|
|                  | (Milligrams per kilogram)* |
| Arsenic          | 75                         |
| Cadmium          | 85                         |
| Chromium         | 3000                       |
| Copper           | 4300                       |
| Lead             | 840                        |
| Mercury          | 57                         |
| Molybdenum       | 75                         |
| Nickel           | 420                        |
| PCBs             | 49                         |
| Selenium         | 100                        |
| Zinc             | 7500                       |

<sup>\*</sup> Dry weight basis

#### 3. Pathogen Control

All sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site must be treated by one of the following methods to ensure that the sludge meets either the Class A, Class AB or Class B biosolids pathogen requirements.

a. For sewage sludge to be classified as Class A biosolids with respect to pathogens, the density of fecal coliform in the sewage sludge must be less than 1,000 most probable number (MPN) per gram of total solids (dry weight basis), or the density of Salmonella sp. bacteria in the sewage sludge must be less than three MPN per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. In addition, one of the alternatives listed below must be met:

<u>Alternative 1</u> - The temperature of the sewage sludge that is used or disposed shall be maintained at or above a specific value for a period of time. See 30 TAC § 312.82(a)(2)(A) for specific information;

Alternative 5 (PFRP) - Sewage sludge that is used or disposed of must be treated in one of the Processes to Further Reduce Pathogens (PFRP) described in 40 CFR Part 503, Appendix B. PFRP include composting, heat drying, heat treatment, and thermophilic aerobic digestion; or

Alternative 6 (PFRP Equivalent) - Sewage sludge that is used or disposed of must be treated in a process that has been approved by the U. S. Environmental Protection Agency as being equivalent to those in Alternative 5.

b. For sewage sludge to be classified as Class AB biosolids with respect to pathogens, the density of fecal coliform in the sewage sludge must be less than 1,000 MPN per gram of total solids (dry weight basis), or the density of *Salmonella* sp. bacteria in the sewage sludge be less than three MPN per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. In addition, one of the alternatives listed below must be met:

<u>Alternative 2</u> - The pH of the sewage sludge that is used or disposed shall be raised to above 12 std. units and shall remain above 12 std. units for 72 hours.

The temperature of the sewage sludge shall be above 52° Celsius for 12 hours or longer during the period that the pH of the sewage sludge is above 12 std. units.

At the end of the 72-hour period during which the pH of the sewage sludge is above 12 std. units, the sewage sludge shall be air dried to achieve a percent solids in the sewage sludge greater than 50%; or

Alternative 3 - The sewage sludge shall be analyzed for enteric viruses prior to pathogen treatment. The limit for enteric viruses is less than one Plaque-forming Unit per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 30 TAC § 312.82(a)(2)(C)(i-iii) for specific information. The sewage sludge shall be analyzed for viable helminth ova prior to pathogen treatment. The limit for viable helminth ova is less than one per four grams of total solids (dry weight basis) either before or following pathogen treatment. See 30 TAC § 312.82(a)(2)(C)(iv-vi) for specific information; or

<u>Alternative 4</u> - The density of enteric viruses in the sewage sludge shall be less than one Plaque-forming Unit per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed. The density of viable helminth ova in the sewage sludge shall be less than one per four grams of total solids (dry weight basis) at the time the sewage sludge is used or disposed.

- c. Sewage sludge that meets the requirements of Class AB biosolids may be classified a Class A biosolids if a variance request is submitted in writing that is supported by substantial documentation demonstrating equivalent methods for reducing odors and written approval is granted by the executive director. The executive director may deny the variance request or revoke that approved variance if it is determined that the variance may potentially endanger human health or the environment, or create nuisance odor conditions.
- d. Three alternatives are available to demonstrate compliance with Class B biosolids criteria.

#### Alternative 1

- i. A minimum of seven random samples of the sewage sludge shall be collected within 48 hours of the time the sewage sludge is used or disposed of during each monitoring episode for the sewage sludge.
- ii. The geometric mean of the density of fecal coliform in the samples collected shall be less than either 2,000,000 MPN per gram of total solids (dry weight basis) or 2,000,000 Colony Forming Units per gram of total solids (dry weight basis).

<u>Alternative 2</u> - Sewage sludge that is used or disposed of shall be treated in one of the Processes to Significantly Reduce Pathogens (PSRP) described in 40 CFR Part 503, Appendix B, so long as all of the following requirements are met by the generator of the sewage sludge.

- i. Prior to use or disposal, all the sewage sludge must have been generated from a single location, except as provided in paragraph v. below;
- ii. An independent Texas Licensed Professional Engineer must make a certification to the generator of a sewage sludge that the wastewater treatment facility generating the sewage sludge is designed to achieve one of the PSRP at the permitted design loading of the facility. The certification need only be repeated if the design loading of the facility is increased. The certification shall include a statement indicating the design meets all the applicable standards specified in Appendix B of 40 CFR Part 503;
- iii. Prior to any off-site transportation or on-site use or disposal of any sewage sludge generated at a wastewater treatment facility, the chief certified operator of the wastewater treatment facility or other responsible official who manages the processes to significantly reduce pathogens at the wastewater treatment facility for the permittee, shall certify that the sewage sludge underwent at least the minimum operational requirements necessary in order to meet one of the PSRP. The acceptable processes and the minimum operational and record keeping requirements shall be in accordance with established U.S. Environmental Protection Agency final guidance;
- iv. All certification records and operational records describing how the requirements of this paragraph were met shall be kept by the generator for a minimum of three years and be available for inspection by commission staff for review; and
- v. If the sewage sludge is generated from a mixture of sources, resulting from a person who prepares sewage sludge from more than one wastewater treatment facility, the resulting derived product shall meet one of the PSRP, and shall meet the certification, operation, and record keeping requirements of this paragraph.

<u>Alternative 3</u> - Sewage sludge shall be treated in an equivalent process that has been approved by the U.S. Environmental Protection Agency, so long as all of the following requirements are met by the generator of the sewage sludge.

i. Prior to use or disposal, all the sewage sludge must have been generated from a single location, except as provided in paragraph v. below;

- ii. Prior to any off-site transportation or on-site use or disposal of any sewage sludge generated at a wastewater treatment facility, the chief certified operator of the wastewater treatment facility or other responsible official who manages the processes to significantly reduce pathogens at the wastewater treatment facility for the permittee, shall certify that the sewage sludge underwent at least the minimum operational requirements necessary in order to meet one of the PSRP. The acceptable processes and the minimum operational and record keeping requirements shall be in accordance with established U.S. Environmental Protection Agency final guidance;
- iii. All certification records and operational records describing how the requirements of this paragraph were met shall be kept by the generator for a minimum of three years and be available for inspection by commission staff for review;
- iv. The Executive Director will accept from the U.S. Environmental Protection Agency a finding of equivalency to the defined PSRP; and
- v. If the sewage sludge is generated from a mixture of sources resulting from a person who prepares sewage sludge from more than one wastewater treatment facility, the resulting derived product shall meet one of the Processes to Significantly Reduce Pathogens, and shall meet the certification, operation, and record keeping requirements of this paragraph.

In addition to the Alternatives 1 - 3, the following site restrictions must be met if Class B biosolids are land applied:

- i. Food crops with harvested parts that touch the biosolids/soil mixture and are totally above the land surface shall not be harvested for 14 months after application of biosolids.
- ii. Food crops with harvested parts below the surface of the land shall not be harvested for 20 months after application of biosolids when the biosolids remain on the land surface for 4 months or longer prior to incorporation into the soil.
- iii. Food crops with harvested parts below the surface of the land shall not be harvested for 38 months after application of biosolids when the biosolids remain on the land surface for less than 4 months prior to incorporation into the soil.
- iv. Food crops, feed crops, and fiber crops shall not be harvested for 30 days after application of biosolids.
- v. Domestic livestock shall not be allowed to graze on the land for 30 days after application of biosolids.
- vi. Turf grown on land where biosolids are applied shall not be harvested for 1 year after application of the biosolids when the harvested turf is placed on either land with a high potential for public exposure or a lawn.
- vii. Public access to land with a high potential for public exposure shall be restricted for 1 year after application of biosolids.

- viii. Public access to land with a low potential for public exposure shall be restricted for 30 days after application of biosolids.
- ix. Land application of biosolids shall be in accordance with the buffer zone requirements found in 30 TAC § 312.44.

#### 4. Vector Attraction Reduction Requirements

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, or a reclamation site shall be treated by one of the following Alternatives 1 through 10 for vector attraction reduction.

- Alternative 1 The mass of volatile solids in the sewage sludge shall be reduced by a minimum of 38%.
- Alternative 2 If Alternative 1 cannot be met for an anaerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge anaerobically in the laboratory in a bench-scale unit for 40 additional days at a temperature between 30° and 37° Celsius. Volatile solids must be reduced by less than 17% to demonstrate compliance.
- Alternative 3 If Alternative 1 cannot be met for an aerobically digested sludge, demonstration can be made by digesting a portion of the previously digested sludge with percent solids of two percent or less aerobically in the laboratory in a bench-scale unit for 30 additional days at 20° Celsius. Volatile solids must be reduced by less than 15% to demonstrate compliance.
- Alternative 4 The specific oxygen uptake rate (SOUR) for sewage sludge treated in an aerobic process shall be equal to or less than 1.5 milligrams of oxygen per hour per gram of total solids (dry weight basis) at a temperature of 20° Celsius.
- Alternative 5 Sewage sludge shall be treated in an aerobic process for 14 days or longer. During that time, the temperature of the sewage sludge shall be higher than 40° Celsius and the average temperature of the sewage sludge shall be higher than 45° Celsius.
- Alternative 6 The pH of sewage sludge shall be raised to 12 or higher by alkali addition and, without the addition of more alkali shall remain at 12 or higher for two hours and then remain at a pH of 11.5 or higher for an additional 22 hours at the time the sewage sludge is prepared for sale or given away in a bag or other container.
- Alternative 7 The percent solids of sewage sludge that does not contain unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 75% based on the moisture content and total solids prior to mixing with other materials. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

#### Alternative 8 -

The percent solids of sewage sludge that contains unstabilized solids generated in a primary wastewater treatment process shall be equal to or greater than 90% based on the moisture content and total solids prior to mixing with other materials at the time the sludge is used. Unstabilized solids are defined as organic materials in sewage sludge that have not been treated in either an aerobic or anaerobic treatment process.

#### Alternative 9 -

- i. Biosolids shall be injected below the surface of the land.
- ii. No significant amount of the biosolids shall be present on the land surface within one hour after the biosolids are injected.
- iii. When sewage sludge that is injected below the surface of the land is Class A or Class AB with respect to pathogens, the biosolids shall be injected below the land surface within eight hours after being discharged from the pathogen treatment process.

#### Alternative 10-

- i. Biosolids applied to the land surface or placed on a surface disposal site shall be incorporated into the soil within six hours after application to or placement on the land.
- ii. When biosolids that are incorporated into the soil is Class A or Class AB with respect to pathogens, the biosolids shall be applied to or placed on the land within eight hours after being discharged from the pathogen treatment process.

#### C. Monitoring Requirements

Toxicity Characteristic Leaching Procedure - annually (TCLP) Test
PCBs - annually

All metal constituents and fecal coliform or *Salmonella* sp. bacteria shall be monitored at the appropriate frequency shown below, pursuant to 30 TAC § 312.46(a)(1):

| Amount of biosolids (*)<br>metric tons per 365-day period | Monitoring Frequency |
|---|----------------------|
| o to less than 290  | Once/Year            |
| 290 to less than 1,500                                    | Once/Quarter         |
| 1,500 to less than 15,000                                 | Once/Two Months      |
| 15,000 or greater   | Once/Month           |

(\*) The amount of bulk biosolids applied to the land (dry wt. basis).

Representative samples of sewage sludge shall be collected and analyzed in accordance with the methods referenced in 30 TAC § 312.7

Identify each of the analytic methods used by the facility to analyze enteric viruses, fecal coliforms, helminth ova, *Salmonella* sp., and other regulated parameters.

Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.

Identify the nature of material generated by the facility (such as a biosolid for beneficial use or land-farming, or sewage sludge or biosolids for disposal at a monofill) and whether the material is ultimately conveyed off-site in bulk or in bags.

# SECTION II. REQUIREMENTS SPECIFIC TO BULK SEWAGE SLUDGE OR BIOSOLIDS FOR APPLICATION TO THE LAND MEETING CLASS A, CLASS AB or B PATHOGEN REDUCTION AND THE CUMULATIVE LOADING RATES IN TABLE 2, OR CLASS B PATHOGEN REDUCTION AND THE POLLUTANT CONCENTRATIONS IN TABLE 3

For those permittees meeting Class A, Class AB or B pathogen reduction requirements and that meet the cumulative loading rates in Table 2 below, or the Class B pathogen reduction requirements and contain concentrations of pollutants below listed in Table 3, the following conditions apply:

#### A. Pollutant Limits

#### Table 2

|                  | Cumulative Pollutant Loading<br>Rate |
|------------------|--------------------------------------|
| <u>Pollutant</u> | (pounds per acre)*                   |
| Arsenic          | 36                                   |
| Cadmium          | 35                                   |
| Chromium         | 2677                                 |
| Copper           | 1339                                 |
| Lead             | 268                                  |
| Mercury          | 15                                   |
| Molybdenum       | Report Only                          |
| Nickel           | 375                                  |
| Selenium         | 89                                   |
| Zinc             | 2500                                 |
|                  |                                      |

#### Table 3

|                  | Monthly Average            |
|------------------|----------------------------|
|                  | Concentration              |
| <u>Pollutant</u> | (milligrams per kilogram)* |
| Arsenic          | 41                         |
| Cadmium          | 39                         |
| Chromium         | 1200                       |
| Copper           | 1500                       |
| Lead             | 300                        |
| Mercury          | 17                         |
| Molybdenum       | Report Only                |
| Nickel           | 420                        |
| Selenium         | 36                         |
| Zinc             | 2800                       |

<sup>\*</sup>Dry weight basis

#### **B.** Pathogen Control

All bulk sewage sludge that is applied to agricultural land, forest, a public contact site, a reclamation site, shall be treated by either Class A, Class AB or Class B biosolids pathogen reduction requirements as defined above in Section I.B.3.

#### C. Management Practices

- 1. Bulk biosolids shall not be applied to agricultural land, forest, a public contact site, or a reclamation site that is flooded, frozen, or snow-covered so that the bulk sewage sludge enters a wetland or other waters in the State.
- 2. Bulk biosolids not meeting Class A requirements shall be land applied in a manner which complies with Applicability in accordance with 30 TAC §312.41 and the Management Requirements in accordance with 30 TAC § 312.44.
- 3. Bulk biosolids shall be applied at or below the agronomic rate of the cover crop.
- 4. An information sheet shall be provided to the person who receives bulk Class A or AB biosolids sold or given away. The information sheet shall contain the following information:
  - a. The name and address of the person who prepared the Class A or AB biosolids that are sold or given away in a bag or other container for application to the land.
  - b. A statement that application of the biosolids to the land is prohibited except in accordance with the instruction on the label or information sheet.
  - c. The annual whole sludge application rate for the biosolids application rate for the biosolids that does not cause any of the cumulative pollutant loading rates in Table 2 above to be exceeded, unless the pollutant concentrations in Table 3 found in Section II above are met.

#### **D. Notification Requirements**

- 1. If bulk is applied to land in a State other than Texas, written notice shall be provided prior to the initial land application to the permitting authority for the State in which the bulk biosolids are proposed to be applied. The notice shall include:
  - a. The location, by street address, and specific latitude and longitude, of each land application site.
  - b. The approximate time period bulk biosolids will be applied to the site.
  - c. The name, address, telephone number, and National Pollutant Discharge Elimination System permit number (if appropriate) for the person who will apply the bulk biosolids.
- 2. The permittee shall give 180 days prior notice to the Executive Director in care of the Wastewater Permitting Section (MC 148) of the Water Quality Division of any change planned in the biosolids disposal practice.

#### E. Record Keeping Requirements

The documents will be retained at the facility site and/or shall be readily available for review by a TCEQ representative. The person who prepares bulk sewage sludge or a biosolids material shall develop the following information and shall retain the information at the facility site and/or shall be readily available for review by a TCEQ representative for a

period of <u>five years</u>. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for record keeping found in 30 TAC § 312.47 for persons who land apply.

- 1. The concentration (mg/kg) in the sludge of each pollutant listed in Table 3 above and the applicable pollutant concentration criteria (mg/kg), or the applicable cumulative pollutant loading rate and the applicable cumulative pollutant loading rate limit (lbs/ac) listed in Table 2 above.
- 2. A description of how the pathogen reduction requirements are met (including site restrictions for Class AB and Class B biosolids, if applicable).
- 3. A description of how the vector attraction reduction requirements are met.
- 4. A description of how the management practices listed above in Section II.C are being met
- 5. The following certification statement:

"I certify, under penalty of law, that the applicable pathogen requirements in 30 TAC § 312.82(a) or (b) and the vector attraction reduction requirements in 30 TAC § 312.83(b) have been met for each site on which bulk biosolids are applied. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the management practices have been met. I am aware that there are significant penalties for false certification including fine and imprisonment."

- 6. The recommended agronomic loading rate from the references listed in Section II.C.3. above, as well as the actual agronomic loading rate shall be retained. The person who applies bulk biosolids shall develop the following information and shall retain the information at the facility site and/or shall be readily available for review by a TCEQ representative <u>indefinitely</u>. If the permittee supplies the sludge to another person who land applies the sludge, the permittee shall notify the land applier of the requirements for record keeping found in 30 TAC § 312.47 for persons who land apply:
  - a. A certification statement that all applicable requirements (specifically listed) have been met, and that the permittee understands that there are significant penalties for false certification including fine and imprisonment. See 30 TAC § 312.47(a)(4)(A)(ii) or 30 TAC § 312.47(a)(5)(A)(ii), as applicable, and to the permittee's specific sludge treatment activities.
  - b. The location, by street address, and specific latitude and longitude, of each site on which biosolids are applied.
  - c. The number of acres in each site on which bulk biosolids are applied.
  - d. The date and time biosolids are applied to each site.
  - e. The cumulative amount of each pollutant in pounds/acre listed in Table 2 applied to each site.
  - f. The total amount of biosolids applied to each site in dry tons.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

#### F. Reporting Requirements

The permittee shall report annually to the TCEQ Regional Office (MC Region 11) and Compliance Monitoring Team (MC 224) of the Enforcement Division, by September 30<sup>th</sup> of each year the following information. Effective December 21, 2025, the permittee must submit this annual report using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver.

- 1. Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
- 2. Identify the nature of material generated by the facility (such as a biosolid for beneficial use or land-farming, or sewage sludge for disposal at a monofill) and whether the material is ultimately conveyed off-site in bulk or in bags.
- 3. Results of tests performed for pollutants found in either Table 2 or 3 as appropriate for the permittee's land application practices.
- 4. The frequency of monitoring listed in Section I.C. that applies to the permittee.
- 5. Toxicity Characteristic Leaching Procedure (TCLP) results.
- 6. PCB concentration in sludge or biosolids in mg/kg.
- 7. Identity of hauler(s) and TCEQ transporter number.
- 8. Date(s) of transport.
- 9. Texas Commission on Environmental Quality registration number, if applicable.
- 10. Amount of sludge or biosolids disposal dry weight (lbs/acre) at each disposal site.
- 11. The concentration (mg/kg) in the sludge of each pollutant listed in Table 1 (defined as a monthly average) as well as the applicable pollutant concentration criteria (mg/kg) listed in Table 3 above, or the applicable pollutant loading rate limit (lbs/acre) listed in Table 2 above if it exceeds 90% of the limit.
- 12. Level of pathogen reduction achieved (Class A, Class AB or Class B).
- 13. Alternative used as listed in Section I.B.3.(a. or b.). Alternatives describe how the pathogen reduction requirements are met. If Class B biosolids, include information on how site restrictions were met.
- 14. Identify each of the analytic methods used by the facility to analyze enteric viruses, fecal coliforms, helminth ova, *Salmonella* sp., and other regulated parameters.
- 15. Vector attraction reduction alternative used as listed in Section I.B.4.

- 16. Amount of sludge or biosolids transported in dry tons/year.
- 17. The certification statement listed in either 30 TAC § 312.47(a)(4)(A)(ii) or 30 TAC § 312.47(a)(5)(A)(ii) as applicable to the permittee's sludge or biosolids treatment activities, shall be attached to the annual reporting form.
- 18. When the amount of any pollutant applied to the land exceeds 90% of the cumulative pollutant loading rate for that pollutant, as described in Table 2, the permittee shall report the following information as an attachment to the annual reporting form.
  - a. The location, by street address, and specific latitude and longitude.
  - b. The number of acres in each site on which bulk biosolids are applied.
  - c. The date and time bulk biosolids are applied to each site.
  - d. The cumulative amount of each pollutant (i.e., pounds/acre) listed in Table 2 in the bulk biosolids applied to each site.
  - e. The amount of biosolids (i.e., dry tons) applied to each site.

The above records shall be maintained on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

## SECTION III. REQUIREMENTS APPLYING TO ALL SEWAGE SLUDGE OR BIOSOLIDS DISPOSED IN A MUNICIPAL SOLID WASTE LANDFILL

- A. The permittee shall handle and dispose of sewage sludge or biosolids in accordance with 30 TAC § 330 and all other applicable state and federal regulations to protect public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present. The permittee shall ensure that the sewage sludge meets the requirements in 30 TAC § 330 concerning the quality of the sludge or biosolids disposed in a municipal solid waste landfill.
- B. If the permittee generates sewage sludge and supplies that sewage sludge or biosolids to the owner or operator of a municipal solid waste landfill (MSWLF) for disposal, the permittee shall provide to the owner or operator of the MSWLF appropriate information needed to be in compliance with the provisions of this permit.
- C. The permittee shall give 180 days prior notice to the Executive Director in care of the Wastewater Permitting Section (MC 148) of the Water Quality Division of any change planned in the sewage sludge or biosolids disposal practice.
- D. Sewage sludge or biosolids shall be tested annually in accordance with the method specified in both 40 CFR Part 261, Appendix II and 40 CFR Part 268, Appendix I (Toxicity Characteristic Leaching Procedure) or other method, which receives the prior approval of the TCEQ for contaminants listed in Table 1 of 40 CFR § 261.24. Sewage sludge or biosolids failing this test shall be managed according to RCRA standards for generators of hazardous waste, and the waste's disposition must be in accordance with all applicable requirements for hazardous waste processing, storage, or disposal.

Following failure of any TCLP test, the management or disposal of sewage sludge or biosolids at a facility other than an authorized hazardous waste processing, storage, or disposal facility shall be prohibited until such time as the permittee can demonstrate the sewage sludge or biosolids no longer exhibits the hazardous waste toxicity characteristics (as demonstrated by the results of the TCLP tests). A written report shall be provided to both the TCEQ Registration and Reporting Section (MC 129) of the Permitting and Registration Support Division and the Regional Director (MC Region 11) of the appropriate TCEQ field office within 7 days after failing the TCLP Test.

The report shall contain test results, certification that unauthorized waste management has stopped and a summary of alternative disposal plans that comply with RCRA standards for the management of hazardous waste. The report shall be addressed to: Director, Permitting and Registration Support Division (MC 129), Texas Commission on Environmental Quality, P. O. Box 13087, Austin, Texas 78711-3087. In addition, the permittee shall prepare an annual report on the results of all sludge toxicity testing. This annual report shall be submitted to the TCEQ Regional Office (MC Region 11) and the Compliance Monitoring Team (MC 224) of the Enforcement Division by September 30 of each year.

- E. Sewage sludge or biosolids shall be tested as needed, in accordance with the requirements of 30 TAC Chapter 330.
- F. Record Keeping Requirements

The permittee shall develop the following information and shall retain the information for five years.

- 1. The description (including procedures followed and the results) of all liquid Paint Filter Tests performed.
- 2. The description (including procedures followed and results) of all TCLP tests performed.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

#### G. Reporting Requirements

The permittee shall report annually to the TCEQ Regional Office (MC Region 11) and Compliance Monitoring Team (MC 224) of the Enforcement Division by September 30<sup>th</sup> of each year the following information. Effective December 21, 2025, the permittee must submit this annual report using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver.

- 1. Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
- 2. Toxicity Characteristic Leaching Procedure (TCLP) results.
- 3. Annual sludge or biosolids production in dry tons/year.
- 4. Amount of sludge or biosolids disposed in a municipal solid waste landfill in dry tons/year.
- 5. Amount of sludge or biosolids transported interstate in dry tons/year.
- 6. A certification that the sewage sludge or biosolids meets the requirements of 30 TAC § 330 concerning the quality of the sludge disposed in a municipal solid waste landfill.
- 7. Identity of hauler(s) and transporter registration number.
- 8. Owner of disposal site(s).
- 9. Location of disposal site(s).
- 10. Date(s) of disposal.

The above records shall be maintained on-site on a monthly basis and shall be made available to the Texas Commission on Environmental Quality upon request.

## SECTION IV. REQUIREMENTS APPLYING TO SLUDGE OR BIOSOLIDS TRANSPORTED TO ANOTHER FACILITY FOR FURTHER PROCESSING

These provisions apply to sludge or biosolids that is transported to another wastewater treatment facility or facility that further processes sludge or biosolids. These provisions are intended to allow transport of sludge or biosolids to facilities that have been authorized to accept sludge or biosolids. These provisions do not limit the ability of the receiving facility to determine whether to accept the sludge or biosolids, nor do they limit the ability of the receiving facility to request additional testing or documentation.

#### A. General Requirements

- 1. The permittee shall handle and dispose of sewage sludge or biosolids in accordance with 30 TAC Chapter 312 and all other applicable state and federal regulations in a manner that protects public health and the environment from any reasonably anticipated adverse effects due to any toxic pollutants that may be present in the sludge.
- 2. Sludge or biosolids may only be transported using a registered transporter or using an approved pipeline.

#### **B.** Record Keeping Requirements

- 1. For sludge transported by an approved pipeline, the permittee must maintain records of the following:
  - a. the amount of sludge or biosolids transported;
  - b. the date of transport;
  - c. the name and TCEO permit number of the receiving facility or facilities;
  - d. the location of the receiving facility or facilities;
  - e. the name and TCEQ permit number of the facility that generated the waste; and
  - f. copy of the written agreement between the permittee and the receiving facility to accept sludge or biosolids.
- 2. For sludge or biosolids transported by a registered transporter, the permittee must maintain records of the completed trip tickets in accordance with 30 TAC § 312.145(a)(1)-(7) and amount of sludge or biosolids transported.
- 3. The above records shall be maintained on-site on a monthly basis and shall be made available to the TCEQ upon request. These records shall be retained for at least five years.

#### C. Reporting Requirements

The permittee shall report the following information annually to the TCEQ Regional Office (MC Region 11) and Compliance Monitoring Team (MC 224) of the Enforcement Division, by September 30<sup>th</sup> of each year. Effective December 21, 2025, the permittee must submit this annual report using the online electronic reporting system available through the TCEQ website unless the permittee requests and obtains an electronic reporting waiver.

- 1. Identify in the following categories (as applicable) the sewage sludge or biosolids treatment process or processes at the facility: preliminary operations (e.g., sludge or biosolids grinding and degritting), thickening (concentration), stabilization, anaerobic digestion, aerobic digestion, composting, conditioning, disinfection (e.g., beta ray irradiation, gamma ray irradiation, pasteurization), dewatering (e.g., centrifugation, sludge drying beds, sludge lagoons), heat drying, thermal reduction, and methane or biogas capture and recovery.
- 2. the annual sludge or biosolids production;
- 3. the amount of sludge or biosolids transported;
- 4. the owner of each receiving facility;
- 5. the location of each receiving facility; and
- 6. the date(s) of disposal at each receiving facility.

TCEQ Revision 06/2020

#### OTHER REQUIREMENTS

- 1. The permittee shall employ or contract with one or more licensed wastewater treatment facility operators or wastewater system operations companies holding a valid license or registration according to the requirements of 30 TAC Chapter 30, Occupational Licenses and Registrations, and in particular 30 TAC Chapter 30, Subchapter J, Wastewater Operators and Operations Companies.
  - This Category B facility in the Interim I phase and Category A facility in the Interim II and Final phases must be operated by a chief operator or an operator holding a Class B license or higher in the Interim I phase and Class A license or higher in the Interim II and Final phases. The facility must be operated a minimum of five days per week by the licensed chief operator or an operator holding the required level of license or higher. The licensed chief operator or operator holding the required level of license or higher must be available by telephone or pager seven days per week. Where shift operation of the wastewater treatment facility is necessary, each shift that does not have the on-site supervision of the licensed chief operator must be supervised by an operator in charge who is licensed not less than one level below the category for the facility.
- 2. The facility is not located in the Coastal Management Program boundary.
- 3. Chronic toxic criteria apply at the edge of the mixing zone. The mixing zone is defined as 300 feet downstream and 100 feet upstream from the point of discharge.
- 4. The permittee shall comply with the requirements of 30 TAC § 309.13(a) through (d). In addition, by ownership of the required buffer zone area, the permittee shall comply with the requirements of 30 TAC § 309.13(e).
- 5. The permittee shall provide facilities for the protection of its wastewater treatment facility from a 100-year flood.
- 6. In accordance with 30 TAC § 319.9, a permittee that has at least twelve months of uninterrupted compliance with its bacteria limit may notify the commission in writing of its compliance and request a less frequent measurement schedule. To request a less frequent schedule, the permittee shall submit a written request to the TCEQ Wastewater Permitting Section (MC 148) for each phase that includes a different monitoring frequency. The request must contain all of the reported bacteria values (Daily Avg. and Daily Max/Single Grab) for the twelve consecutive months immediately prior to the request. If the Executive Director finds that a less frequent measurement schedule is protective of human health and the environment, the permittee may be given a less frequent measurement schedule. For this permit, daily may be reduced to 5/week in the Interim I, Interim II, and Final phases. A violation of any bacteria limit by a facility that has been granted a less frequent measurement schedule will require the permittee to return to the standard frequency schedule and submit written notice to the TCEQ Wastewater **Permitting Section (MC 148).** The permittee may not apply for another reduction in measurement frequency for at least 24 months from the date of the last violation. The Executive Director may establish a more frequent measurement schedule if necessary to protect human health or the environment.
- 7. Prior to construction of the Interim II and Final phases treatment facilities, the permittee shall submit to the TCEQ Wastewater Permitting Section (MC 148) a summary transmittal

letter in accordance with the requirements in 30 TAC § 217.6(d). If requested by the Wastewater Permitting Section, the permittee shall submit plans, specifications, and a final engineering design report which comply with 30 TAC Chapter 217, Design Criteria for Domestic Wastewater Systems. The permittee shall clearly show how the treatment system will meet the effluent limitations required on Pages 2a and 2b of this permit. A copy of the summary transmittal letter shall be available at the plant site for inspection by authorized representatives of the TCEQ.

Plans and specifications have been approved for the 4.5 MGD (Interim I phase) wastewater treatment facility, in accordance with 30 TAC § 217, Design Criteria for Domestic Wastewater Systems. A summary transmittal approval letter was issued *(January 30, 2022)* (Log No. 0118/032 an 0619/016). A copy of the summary transmittal letter shall be available at the plant site for inspection by authorized representatives of the TCEQ.

8. The permittee shall notify the TCEQ Regional Office (MC Region 11) and the Applications Review and Processing Team (MC 148) of the Water Quality Division, in writing at least forty-five days prior to the completion of the Interim II and Final phases treatment facilities on Notification of Completion Form 20007.

#### CONTRIBUTING INDUSTRIES AND PRETREATMENT REQUIREMENTS

- 1. The following pollutants may not be introduced into the treatment facility:
  - a. Pollutants which create a fire or explosion hazard in the publicly owned treatment works (POTW), including, but not limited to, waste streams with a closed-cup flash point of less than 140° Fahrenheit (60° Celsius) using the test methods specified in 40 CFR § 261.21;
  - b. Pollutants which will cause corrosive structural damage to the POTW, but in no case shall there be discharges with a pH lower than 5.0 standard units, unless the works are specifically designed to accommodate such discharges;
  - c. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW, resulting in Interference;
  - d. Any pollutant, including oxygen-demanding pollutants (e.g., biochemical oxygen demand), released in a discharge at a flow rate and/or pollutant concentration which will cause Interference with the POTW;
  - e. Heat in amounts which will inhibit biological activity in the POTW, resulting in Interference, but in no case shall there be heat in such quantities that the temperature at the POTW treatment plant exceeds 104° Fahrenheit (40° Celsius) unless the Executive Director, upon request of the POTW, approves alternate temperature limits;
  - f. Petroleum oil, nonbiodegradable cutting oil, or products of mineral oil origin in amounts that will cause Interference or Pass Through;
  - g. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems; and
  - h. Any trucked or hauled pollutants except at discharge points designated by the POTW.
- 2. The permittee shall require any indirect discharger to the treatment works to comply with the reporting requirements of Sections 204(b), 307, and 308 of the Clean Water Act, including any requirements established under 40 CFR Part 403 [rev. Federal Register/Vol. 70/No. 198/Friday, October 14, 2005/Rules and Regulations, pages 60134-60798].
- 3. The permittee shall provide adequate notification to the Executive Director, care of the Wastewater Permitting Section (MC 148) of the Water Quality Division, within 30 days subsequent to the permittee's knowledge of either of the following:
  - a. Any new introduction of pollutants into the treatment works from an indirect discharger which would be subject to Sections 301 and 306 of the Clean Water Act if it were directly discharging those pollutants; and
  - b. Any substantial change in the volume or character of pollutants being introduced into the treatment works by a source introducing pollutants into the treatment works at the time of issuance of the permit.

Any notice shall include information on the quality and quantity of effluent to be introduced into the treatment works and any anticipated impact of the change on the quality or quantity of effluent to be discharged from the POTW.

Revised July 2007

#### **BIOMONITORING REQUIREMENTS**

#### CHRONIC BIOMONITORING REQUIREMENTS: FRESHWATER

The provisions of this section apply to Outfall 001 for whole effluent toxicity (WET) testing.

- 1. Scope, Frequency, and Methodology
  - a. The permittee shall test the effluent for toxicity in accordance with the provisions below. Such testing will determine if an appropriately dilute effluent sample adversely affects the survival, reproduction, or growth of the test organisms.
  - b. The permittee shall conduct the following toxicity tests using the test organisms, procedures, and quality assurance requirements specified in this part of this permit and in accordance with "Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms," fourth edition (EPA-821-R-02-013) or its most recent update:
    - 1) Chronic static renewal survival and reproduction test using the water flea (*Ceriodaphnia dubia*) (Method 1002.0). This test should be terminated when 60% of the surviving adults in the control produce three broods or at the end of eight days, whichever occurs first. This test shall be conducted once per quarter.
    - 2) Chronic static renewal 7-day larval survival and growth test using the fathead minnow (*Pimephales promelas*) (Method 1000.0). A minimum of five replicates with eight organisms per replicate shall be used in the control and in each dilution. This test shall be conducted once per quarter.

The permittee must perform and report a valid test for each test species during the prescribed reporting period. An invalid test must be repeated during the same reporting period. An invalid test is defined as any test failing to satisfy the test acceptability criteria, procedures, and quality assurance requirements specified in the test methods and permit.

- c. The permittee shall use five effluent dilution concentrations and a control in each toxicity test. These effluent dilution concentrations are 32%, 42%, 56%, 75%, and 100% effluent. The critical dilution, defined as 100% effluent, is the effluent concentration representative of the proportion of effluent in the receiving water during critical low flow or critical mixing conditions.
- d. This permit may be amended to require a WET limit, a chemical-specific effluent limit, a best management practice, or other appropriate actions to address toxicity. The permittee may be required to conduct a toxicity reduction evaluation (TRE) after multiple toxic events.
- e. Should a test fail (i.e., demonstrate significant toxicity), the testing frequency for that test species increases to monthly until three consecutive tests pass (i.e., do not demonstrate significant toxicity), at which time the testing frequency of once per quarter resumes. If three or more failures are demonstrated during the

permit term for one or both test species, a WET limit will be included for that species in the subsequently reissued permit. Any two lethal failures in a three month period will require the permittee to initiate a TRE (see Part 4. Toxicity Reduction Evaluation).

#### 2. Required Toxicity Testing Conditions

- a. Test Acceptance The permittee shall repeat any toxicity test, including the control and all effluent dilutions, which fail to meet the following criteria:
  - 1) a control mean survival of 80% or greater;
  - 2) a control mean number of water flea neonates per surviving adult of 15 or greater;
  - 3) a control mean dry weight of surviving fathead minnow larvae of 0.25 mg or greater;
  - a control coefficient of variation percent (CV%) of 40 or less in between replicates for the young of surviving females in the water flea test; and the growth and survival endpoints in the fathead minnow test;
  - 5) a critical dilution CV% of 40 or less for the young of surviving females in the water flea test; and the growth and survival endpoints for the fathead minnow test. However, if statistically significant lethal or nonlethal effects are exhibited at the critical dilution, a CV% greater than 40 shall not invalidate the test:
  - 6) a percent minimum significant difference of 47 or less for water flea reproduction; and
  - 7) a percent minimum significant difference of 30 or less for fathead minnow growth.

#### b. Statistical Interpretation

- 1) For the water flea survival test, the statistical analyses used to determine if there is a significant difference between the control and an effluent dilution shall be the Fisher's exact test as described in the manual referenced in Part 1.b.
- 2) For the water flea reproduction test and the fathead minnow larval survival and growth tests, the statistical analyses used to determine if there is a significant difference between the control and an effluent dilution shall be in accordance with the manual referenced in Part 1.b.
- 3) The permittee is responsible for reviewing test concentration-response relationships to ensure that calculated test-results are interpreted and reported correctly. The document entitled "Method Guidance and Recommendation for Whole Effluent Toxicity (WET) Testing (40 CFR Part 136)" (EPA 821-B-00-004) provides guidance on determining the validity of test results.

- 4) If significant lethality is demonstrated (that is, there is a statistically significant difference in survival at the critical dilution when compared to the survival in the control), the conditions of test acceptability are met, and the survival of the test organisms are equal to or greater than 80% in the critical dilution and all dilutions below that, then the permittee shall report a survival No Observed Effect Concentration (NOEC) of not less than the critical dilution for the reporting requirements.
- 5) The NOEC is defined as the greatest effluent dilution at which no significant effect is demonstrated. The Lowest Observed Effect Concentration (LOEC) is defined as the lowest effluent dilution at which a significant effect is demonstrated. A significant effect is defined as a statistically significant difference between the survival, reproduction, or growth of the test organism in a specified effluent dilution when compared to the survival, reproduction, or growth of the test organism in the control.
- 6) The use of NOECs and LOECs assumes either a monotonic (continuous) concentration-response relationship or a threshold model of the concentration-response relationship. For any test result that demonstrates a non-monotonic (non-continuous) response, the NOEC should be determined based on the guidance manual referenced in Item 3.
- 7) Pursuant to the responsibility assigned to the permittee in Part 2.b.3), test results that demonstrate a non-monotonic (non-continuous) concentration-response relationship may be submitted, prior to the due date, for technical review. The guidance manual referenced in Item 3 will be used when making a determination of test acceptability.
- 8) TCEQ staff will review test results for consistency with rules, procedures, and permit requirements.

#### c. Dilution Water

- 1) Dilution water used in the toxicity tests must be the receiving water collected at a point upstream of the discharge point as close as possible to the discharge point but unaffected by the discharge. Where the toxicity tests are conducted on effluent discharges to receiving waters that are classified as intermittent streams, or where the toxicity tests are conducted on effluent discharges where no receiving water is available due to zero flow conditions, the permittee shall:
  - a) substitute a synthetic dilution water that has a pH, hardness, and alkalinity similar to that of the closest downstream perennial water unaffected by the discharge; or
  - b) use the closest downstream perennial water unaffected by the discharge.
- 2) Where the receiving water proves unsatisfactory as a result of pre-existing instream toxicity (i.e. fails to fulfill the test acceptance criteria of Part

- 2.a.), the permittee may substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:
- a) a synthetic lab water control was performed (in addition to the receiving water control) which fulfilled the test acceptance requirements of Part 2.a;
- b) the test indicating receiving water toxicity was carried out to completion (i.e., 7 days); and
- c) the permittee submitted all test results indicating receiving water toxicity with the reports and information required in Part 3.
- 3) The synthetic dilution water shall consist of standard, moderately hard, reconstituted water. Upon approval, the permittee may substitute other appropriate dilution water with chemical and physical characteristics similar to that of the receiving water.

#### d. Samples and Composites

- 1) The permittee shall collect a minimum of three composite samples from Outfall 001. The second and third composite samples will be used for the renewal of the dilution concentrations for each toxicity test.
- 2) The permittee shall collect the composite samples such that the samples are representative of any periodic episode of chlorination, biocide usage, or other potentially toxic substance being discharged on an intermittent basis.
- 3) The permittee shall initiate the toxicity tests within 36 hours after collection of the last portion of the first composite sample. The holding time for any subsequent composite sample shall not exceed 72 hours. Samples shall be maintained at a temperature of 0-6 degrees Centigrade during collection, shipping, and storage.
- 4) If Outfall 001 ceases discharging during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions, and the sample holding time are waived during that sampling period. However, the permittee must have collected an effluent composite sample volume sufficient to complete the required toxicity tests with renewal of the effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days if the discharge occurs over multiple days. The sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report.
- 5) The effluent samples shall not be dechlorinated after sample collection.

## 3. Reporting

All reports, tables, plans, summaries, and related correspondence required in this section shall be submitted to the attention of the Standards Implementation Team (MC 150) of the Water Quality Division.

- a. The permittee shall prepare a full report of the results of all tests conducted in accordance with the manual referenced in Part 1.b. for every valid and invalid toxicity test initiated whether carried to completion or not.
- b. The permittee shall routinely report the results of each biomonitoring test on the Table 1 forms provided with this permit.
  - 1) Annual biomonitoring test results are due on or before January 20th for biomonitoring conducted during the previous 12-month period.
  - 2) Semiannual biomonitoring test results are due on or before July 20th and January 20th for biomonitoring conducted during the previous 6-month period.
  - 3) Quarterly biomonitoring test results are due on or before April 20th, July 20th, October 20th, and January 20th for biomonitoring conducted during the previous calendar quarter.
  - 4) Monthly biomonitoring test results are due on or before the 20th day of the month following sampling.
- c. Enter the following codes for the appropriate parameters for valid tests only:
  - 1) For the water flea, Parameter TLP3B, enter a "1" if the NOEC for survival is less than the critical dilution; otherwise, enter a "0."
  - 2) For the water flea, Parameter TOP3B, report the NOEC for survival.
  - 3) For the water flea, Parameter TXP3B, report the LOEC for survival.
  - 4) For the water flea, Parameter TWP3B, enter a "1" if the NOEC for reproduction is less than the critical dilution; otherwise, enter a "o."
  - 5) For the water flea, Parameter TPP3B, report the NOEC for reproduction.
  - 6) For the water flea, Parameter TYP3B, report the LOEC for reproduction.
  - 7) For the fathead minnow, Parameter TLP6C, enter a "1" if the NOEC for survival is less than the critical dilution; otherwise, enter a "0."
  - 8) For the fathead minnow, Parameter TOP6C, report the NOEC for survival.
  - 9) For the fathead minnow, Parameter TXP6C, report the LOEC for survival.

- For the fathead minnow, Parameter TWP6C, enter a "1" if the NOEC for growth is less than the critical dilution; otherwise, enter a "0."
- 11) For the fathead minnow, Parameter TPP6C, report the NOEC for growth.
- 12) For the fathead minnow, Parameter TYP6C, report the LOEC for growth.

### 4. <u>Toxicity Reduction Evaluation</u>

- a. Within 45 days of the retest that demonstrates significant lethality, or within 45 days of being so instructed due to multiple toxic events, the permittee shall submit a general outline for initiating a TRE. The outline shall include, but not be limited to, a description of project personnel, a schedule for obtaining consultants (if needed), a discussion of influent and effluent data available for review, a sampling and analytical schedule, and a proposed TRE initiation date.
- b. Within 90 days of the retest that demonstrates significant lethality, or within 90 days of being so instructed due to multiple toxic events, the permittee shall submit a TRE action plan and schedule for conducting a TRE. The plan shall specify the approach and methodology to be used in performing the TRE. A TRE is a step-wise investigation combining toxicity testing with physical and chemical analyses to determine actions necessary to eliminate or reduce effluent toxicity to a level not effecting significant lethality at the critical dilution. The TRE action plan shall describe an approach for the reduction or elimination of lethality for both test species defined in Part 1.b. At a minimum, the TRE action plan shall include the following:
  - Specific Activities The TRE action plan shall specify the approach the 1) permittee intends to utilize in conducting the TRE, including toxicity characterizations, identifications, confirmations, source evaluations, treatability studies, and alternative approaches. When conducting characterization analyses, the permittee shall perform multiple characterizations and follow the procedures specified in the document entitled "Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I" (EPA/600/6-91/005F) or alternate procedures. The permittee shall perform multiple identifications and follow the methods specified in the documents entitled "Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/080) and "Methods for Aquatic Toxicity Identification Evaluations: Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/081). All characterization, identification, and confirmation tests shall be conducted in an orderly and logical progression;
  - 2) Sampling Plan The TRE action plan should describe sampling locations, methods, holding times, chain of custody, and preservation techniques. The effluent sample volume collected for all tests shall be adequate to perform the toxicity characterization/identification/confirmation procedures and chemical-specific analyses when the toxicity tests show significant lethality. Where the permittee has identified or suspects a

- specific pollutant and source of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical-specific analyses for the identified and suspected pollutant and source of effluent toxicity;
- 3) Quality Assurance Plan The TRE action plan should address record keeping and data evaluation, calibration and standardization, baseline tests, system blanks, controls, duplicates, spikes, toxicity persistence in the samples, randomization, reference toxicant control charts, and mechanisms to detect artifactual toxicity; and
- 4) Project Organization The TRE action plan should describe the project staff, project manager, consulting engineering services (where applicable), consulting analytical and toxicological services, etc.
- c. Within 30 days of submittal of the TRE action plan and schedule, the permittee shall implement the TRE.
- d. The permittee shall submit quarterly TRE activities reports concerning the progress of the TRE. The quarterly reports are due on or before April 20th, July 20th, October 20th, and January 20th. The report shall detail information regarding the TRE activities including:
  - 1) results and interpretation of any chemical-specific analyses for the identified and suspected pollutant performed during the quarter;
  - 2) results and interpretation of any characterization, identification, and confirmation tests performed during the quarter;
  - any data and substantiating documentation which identifies the pollutant(s) and source of effluent toxicity;
  - 4) results of any studies/evaluations concerning the treatability of the facility's effluent toxicity;
  - 5) any data that identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to meet no significant lethality at the critical dilution; and
  - 6) any changes to the initial TRE plan and schedule that are believed necessary as a result of the TRE findings.
- e. During the TRE, the permittee shall perform, at a minimum, quarterly testing using the more sensitive species. Testing for the less sensitive species shall continue at the frequency specified in Part 1.b.
- f. If the effluent ceases to effect significant lethality, i.e., there is a cessation of lethality, the permittee may end the TRE. A cessation of lethality is defined as no significant lethality for a period of 12 consecutive months with at least monthly testing. At the end of the 12 months, the permittee shall submit a statement of intent to cease the TRE and may then resume the testing frequency specified in Part 1.b.

This provision accommodates situations where operational errors and upsets, spills, or sampling errors triggered the TRE, in contrast to a situation where a single toxicant or group of toxicants cause lethality. This provision does not apply as a result of corrective actions taken by the permittee. Corrective actions are defined as proactive efforts that eliminate or reduce effluent toxicity. These include, but are not limited to, source reduction or elimination, improved housekeeping, changes in chemical usage, and modifications of influent streams and effluent treatment.

The permittee may only apply this cessation of lethality provision once. If the effluent again demonstrates significant lethality to the same species, the permit will be amended to add a WET limit with a compliance period, if appropriate. However, prior to the effective date of the WET limit, the permittee may apply for a permit amendment removing and replacing the WET limit with an alternate toxicity control measure by identifying and confirming the toxicant and an appropriate control measure.

- g. The permittee shall complete the TRE and submit a final report on the TRE activities no later than 28 months from the last test day of the retest that confirmed significant lethal effects at the critical dilution. The permittee may petition the Executive Director (in writing) for an extension of the 28-month limit. However, to warrant an extension the permittee must have demonstrated due diligence in its pursuit of the toxicity identification evaluation/TRE and must prove that circumstances beyond its control stalled the toxicity identification evaluation/TRE. The report shall provide information pertaining to the specific control mechanism selected that will, when implemented, result in the reduction of effluent toxicity to no significant lethality at the critical dilution. The report shall also provide a specific corrective action schedule for implementing the selected control mechanism.
- h. Based on the results of the TRE and proposed corrective actions, this permit may be amended to modify the biomonitoring requirements, where necessary, require a compliance schedule for implementation of corrective actions, specify a WET limit, specify a best management practice, and specify a chemical-specific limit.
- i. Copies of any and all required TRE plans and reports shall also be submitted to the U.S. EPA Region 6 office, 6WQ-PO.

# TABLE 1 (SHEET 1 OF 4)

#### BIOMONITORING REPORTING

#### CERIODAPHNIA DUBIA SURVIVAL AND REPRODUCTION

| Dates and Tim    | nes No. 1     | FROM: _   | Date    | Time        | TO:         | ate Time    |               |
|------------------|---------------|-----------|---------|-------------|-------------|-------------|---------------|
| Composites       |               |           |         |             |             |             |               |
|                  | No. 3         | FROM:_    |         |             | TO:         |             |               |
| Test initiated   | <b>:</b>      |           |         | am/]        | pm          |             | date          |
| Diluti           | on water used | l:        | Recei   | ving wat    | er          | Synthetic D | ilution water |
|                  | NUMBEI        | R OF YOUN | IG PROI | DUCED I     | PER ADULT A | T END OF TE | ST            |
|                  |               |           |         | Percent     | effluent    |             |               |
| REP              | 0%            | 32%       | 4       | <b>42</b> % | 56%         | 75%         | 100%          |
| A                |               |           |         |             |             |             |               |
| В                |               |           |         |             |             |             |               |
| С                |               |           |         |             |             |             |               |
| D                |               |           |         |             |             |             |               |
| Е                |               |           |         |             |             |             |               |
| F                |               |           |         |             |             |             |               |
| G                |               |           |         |             |             |             |               |
| Н                |               |           |         |             |             |             |               |
| I                |               |           |         |             |             |             |               |
| J                |               |           |         |             |             |             |               |
| Survival<br>Mean |               |           |         |             |             |             |               |
| Total<br>Mean    |               |           |         |             |             |             |               |
| CV%*             |               |           |         |             |             |             |               |
| PMSD             |               |           |         |             |             |             |               |

Designate males (M), and dead females (D), along with number of neonates (x) released prior to death.

<sup>\*</sup>Coefficient of Variation = standard deviation x 100/mean (calculation based on young of the surviving adults)

### TABLE 1 (SHEET 2 OF 4)

#### CERIODAPHNIA DUBIA SURVIVAL AND REPRODUCTION TEST

1. Dunnett's Procedure or Steel's Many-One Rank Test or Wilcoxon Rank Sum Test (with Bonferroni adjustment) or t-test (with Bonferroni adjustment) as appropriate:

Is the mean number of young produced per adult significantly less than the number of young per adult in the control for the % effluent corresponding to significant nonlethal effects?

| CRITICAL DILUTION | (100%)   | YES | NO  |
|-------------------|----------|-----|-----|
|                   | (100/0). | 110 | 110 |

#### PERCENT SURVIVAL

|                 | Percent effluent |     |     |     |     |      |  |  |
|-----------------|------------------|-----|-----|-----|-----|------|--|--|
| Time of Reading | 0%               | 32% | 42% | 56% | 75% | 100% |  |  |
| 24h             |                  |     |     |     |     |      |  |  |
| 48h             |                  |     |     |     |     |      |  |  |
| End of Test     |                  |     |     |     |     |      |  |  |

2. Fisher's Exact Test:

Is the mean survival at test end significantly less than the control survival for the % effluent corresponding to lethality?

| CRITICAL DILUTION ( | 100%): | YES | NO |
|---------------------|--------|-----|----|
|                     |        |     |    |

- 3. Enter percent effluent corresponding to each NOEC\LOEC below:
  - a.) NOEC survival = \_\_\_\_\_\_% effluent
  - b.) LOEC survival = \_\_\_\_\_% effluent
  - c.) NOEC reproduction = \_\_\_\_\_\_% effluent
  - d.) LOEC reproduction = \_\_\_\_\_ % effluent

Time

Date

# TABLE 1 (SHEET 3 OF 4)

# BIOMONITORING REPORTING

# FATHEAD MINNOW LARVAE GROWTH AND SURVIVAL

Date Time

| Dates and Times<br>Composites   | No. 1 FR  | No. 1 FROM: TO:  |   |  |                                     |   |               |  |
|---|---|--|---|--|-------------------------------------|---|---------------|--|
| Collected   | No. 2 FR  | OM:  |   |  | TO:                                 |   |               |  |
|   | No. 3 FR  | OM:  |   |  | TO:                                 |   |               |  |
| Test initiated:   |   |  | ;   | am/pm  |                                     |   | date          |  |
| Dilution wat  | er used:  | F  | Receiving v   | water  |                                     | _Synthetic di                                 | llution water |  |
|   |   | FATHEAI  | O MINNO   | W GROW.  | ΓH DATΑ                             | A   |               |  |
| Effluent  | Avera   | ge Dry We  | eight in rep  | olicate cha  | mbers                               | Mean<br>Dry                                   | CV%*          |  |
| Concentration   | A   | В  | С   | D  | Е                                   | Weight  |               |  |
| 0%  |   |  |   |  |                                     |   |               |  |
| 32%   |   |  |   |  |                                     |   |               |  |
| 42%   |   |  |   |  |                                     |   |               |  |
| 56%   |   |  |   |  |                                     |   |               |  |
| 75%   |   |  |   |  |                                     |   |               |  |
| 100%  |   |  |   |  |                                     |   |               |  |
| PMSD  |   | -  |   |  | 1                                   |   |               |  |
| * Coefficient of Varia  1. Dunnett's Pr Bonferroni a  Is the mean of (growth) for | ocedure or S<br>djustment) o<br>dry weight (g<br>the % efflue | Steel's Mar<br>or t-test (w<br>growth) at<br>nt correspo | ny-One Ra<br>vith Bonfer<br>7 days sig<br>onding to | nk Test or<br>roni adjust<br>nificantly<br>significant | stment) a<br>less than<br>t nonleth | as appropriat<br>the control's<br>al effects? | e:            |  |
|   | CKITICAL  | ' DILUTIC  | )N (100%  | бJ:  | YES_                                | NO  |               |  |

# TABLE 1 (SHEET 4 OF 4)

# BIOMONITORING REPORTING

### FATHEAD MINNOW GROWTH AND SURVIVAL TEST

### FATHEAD MINNOW SURVIVAL DATA

| Effluent      | Percent Survival in replicate chambers |   |   |   |   | Mean percent survival |     |       | CV%* |
|---------------|--|---|---|---|---|-----------------------|-----|-------|------|
| Concentration | A                                      | В | С | D | E | 24h                   | 48h | 7 day |      |
| 0%            |  |   |   |   |   |                       |     |       |      |
| 32%           |  |   |   |   |   |                       |     |       |      |
| 42%           |  |   |   |   |   |                       |     |       |      |
| 56%           |  |   |   |   |   |                       |     |       |      |
| 75%           | _                                      |   |   |   | _ |                       |     | _     |      |
| 100%          | -                                      | _ | _ | - | _ | _                     | _   |       |      |

<sup>\*</sup> Coefficient of Variation = standard deviation x 100/mean

| 2. | Dunnett's Procedure or Steel's Many-One Rank Test or Wilcoxon Rank Sum Test (with Bonferroni adjustment) or t-test (with Bonferroni adjustment) as appropriate: |
|----|---|
|    | Is the mean survival at 7 days significantly less than the control survival for the $\%$ effluent corresponding to lethality?                                   |
|    | CRITICAL DILUTION (100%):YESNO  |
| 3. | Enter percent effluent corresponding to each NOEC\LOEC below:   |
|    | a.) NOEC survival =% effluent   |
|    | b.) LOEC survival =% effluent   |
|    | c.) NOEC growth =% effluent   |
|    | d.) LOEC growth =% effluent   |

### 24-HOUR ACUTE BIOMONITORING REQUIREMENTS: FRESHWATER

The provisions of this section apply to Outfall 001 for whole effluent toxicity (WET) testing.

## 1. <u>Scope, Frequency, and Methodology</u>

- a. The permittee shall test the effluent for lethality in accordance with the provisions in this section. Such testing will determine compliance with Texas Surface Water Quality Standard 30 TAC § 307.6(e)(2)(B), which requires greater than 50% survival of the appropriate test organisms in 100% effluent for a 24-hour period.
- b. The toxicity tests specified shall be conducted once per six months. The permittee shall conduct the following toxicity tests using the test organisms, procedures, and quality assurance requirements specified in this section of the permit and in accordance with "Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms," fifth edition (EPA-821-R-02-012) or its most recent update:
  - 1) Acute 24-hour static toxicity test using the water flea (*Daphnia pulex* or *Ceriodaphnia dubia*). A minimum of five replicates with eight organisms per replicate shall be used in the control and each dilution.
  - 2) Acute 24-hour static toxicity test using the fathead minnow (*Pimephales promelas*). A minimum of five replicates with eight organisms per replicate shall be used in the control and each dilution.

A valid test result must be submitted for each reporting period. The permittee must report, and then repeat, an invalid test during the same reporting period. The repeat test shall include the control and the 100% effluent dilution and use the appropriate number of organisms and replicates, as specified above. An invalid test is defined as any test failing to satisfy the test acceptability criteria, procedures, and quality assurance requirements specified in the test methods and permit.

- c. In addition to an appropriate control, a 100% effluent concentration shall be used in the toxicity tests. Except as discussed in item 2.b., the control and dilution water shall consist of standard, synthetic, moderately hard, reconstituted water.
- d. This permit may be amended to require a WET limit, a Best Management Practice (BMP), Chemical-Specific (CS) limits, or other appropriate actions to address toxicity. The permittee may be required to conduct a Toxicity Reduction Evaluation after multiple toxic events.
- e. As the dilution series specified in the Chronic Biomonitoring Requirements includes a 100% effluent concentration, the results from those tests may fulfill the requirements of this Section; any tests performed in the proper time interval may be substituted. Compliance will be evaluated as specified in item a. The 50% survival in 100% effluent for a 24-hour period standard applies to all tests utilizing a 100% effluent dilution, regardless of whether the results are submitted to comply with the minimum testing frequency defined in item b.

## 2. Required Toxicity Testing Conditions

- a. Test Acceptance The permittee shall repeat any toxicity test, including the control, if the control fails to meet a mean survival equal to or greater than 90%.
- b. Dilution Water In accordance with item 1.c., the control and dilution water shall normally consist of standard, synthetic, moderately hard, reconstituted water. If the permittee utilizes the results of a chronic test to satisfy the requirements in item 1.e., the permittee may use the receiving water or dilution water that meets the requirements of item 2.a as the control and dilution water.

#### c. Samples and Composites

- 1) The permittee shall collect one composite sample from Outfall 001.
- 2) The permittee shall collect the composite sample such that the sample is representative of any periodic episode of chlorination, biocide usage, or other potentially toxic substance being discharged.
- 3) The permittee shall initiate the toxicity tests within 36 hours after collection of the last portion of the composite sample. The sample shall be maintained at a temperature of o-6 degrees Centigrade during collection, shipping, and storage.
- 4) If Outfall 001 ceases discharging during the collection of the effluent composite sample, the requirements for the minimum number of effluent portions are waived. However, the permittee must have collected a composite sample volume sufficient for completion of the required test. The abbreviated sample collection, duration, and methodology must be documented in the full report.
- 5) The effluent sample shall not be dechlorinated after sample collection.

#### 3. Reporting

All reports, tables, plans, summaries, and related correspondence required in this section shall be submitted to the attention of the Standards Implementation Team (MC 150) of the Water Quality Division.

- a. The permittee shall prepare a full report of the results of all tests conducted in accordance with the manual referenced in Part 1.b. for every valid and invalid toxicity test initiated.
- b. The permittee shall routinely report the results of each biomonitoring test on the Table 2 forms provided with this permit.
  - 1) Semiannual biomonitoring test results are due on or before July 20th and January 20th for biomonitoring conducted during the previous 6-month period.

- 2) Quarterly biomonitoring test results are due on or before April 20th, July 20th, and October 20th, and January 20th for biomonitoring conducted during the previous calendar quarter.
- c. Enter the following codes for the appropriate parameters for valid tests only:
  - 1) For the water flea, Parameter TIE3D, enter a "0" if the mean survival at 24 hours is greater than 50% in the 100% effluent dilution; if the mean survival is less than or equal to 50%, enter a "1."
  - 2) For the fathead minnow, Parameter TIE6C, enter a "0" if the mean survival at 24 hours is greater than 50% in the 100% effluent dilution; if the mean survival is less than or equal to 50%, enter a "1."
- d. Enter the following codes for retests only:
  - 1) For retest number 1, Parameter 22415, enter a "0" if the mean survival at 24 hours is greater than 50% in the 100% effluent dilution; if the mean survival is less than or equal to 50%, enter a "1."
  - 2) For retest number 2, Parameter 22416, enter a "0" if the mean survival at 24 hours is greater than 50% in the 100% effluent dilution; if the mean survival is less than or equal to 50%, enter a "1."

#### 4. <u>Persistent Mortality</u>

The requirements of this part apply when a toxicity test demonstrates significant lethality, which is defined as a mean mortality of 50% or greater of organisms exposed to the 100% effluent concentration for 24 hours.

- a. The permittee shall conduct 2 additional tests (retests) for each species that demonstrates significant lethality. The two retests shall be conducted once per week for 2 weeks. Five effluent dilution concentrations in addition to an appropriate control shall be used in the retests. These effluent concentrations are 6%, 13%, 25%, 50% and 100% effluent. The first retest shall be conducted within 15 days of the laboratory determination of significant lethality. All test results shall be submitted within 20 days of test completion of the second retest. Test completion is defined as the 24th hour.
- b. If one or both of the two retests specified in Part 4.a. demonstrates significant lethality, the permittee shall initiate the TRE requirements as specified in Part 5.

#### 5. <u>Toxicity Reduction Evaluation</u>

a. Within 45 days of the retest that demonstrates significant lethality, the permittee shall submit a general outline for initiating a TRE. The outline shall include, but not be limited to, a description of project personnel, a schedule for obtaining consultants (if needed), a discussion of influent and effluent data available for review, a sampling and analytical schedule, and a proposed TRE initiation date.

- b. Within 90 days of the retest that demonstrates significant lethality, the permittee shall submit a TRE action plan and schedule for conducting a TRE. The plan shall specify the approach and methodology to be used in performing the TRE. A TRE is a step-wise investigation combining toxicity testing with physical and chemical analyses to determine actions necessary to eliminate or reduce effluent toxicity to a level not effecting significant lethality at the critical dilution. The TRE action plan shall lead to the successful elimination of significant lethality for both test species defined in Part 1.b. At a minimum, the TRE action plan shall include the following:
  - 1) Specific Activities - The TRE action plan shall specify the approach the permittee intends to utilize in conducting the TRE, including toxicity characterizations, identifications, confirmations, source evaluations, treatability studies, and alternative approaches. When conducting characterization analyses, the permittee shall perform multiple characterizations and follow the procedures specified in the document entitled "Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures" (EPA/600/6-91/003) or alternate procedures. The permittee shall perform multiple identifications and follow the methods specified in the documents entitled "Methods for Aguatic Toxicity Identification Evaluations: Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/080) and "Methods for Aquatic Toxicity Identification Evaluations: Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity" (EPA/600/R-92/081). All characterization, identification, and confirmation tests shall be conducted in an orderly and logical progression:
  - 2) Sampling Plan The TRE action plan should describe sampling locations, methods, holding times, chain of custody, and preservation techniques. The effluent sample volume collected for all tests shall be adequate to perform the toxicity characterization/identification/confirmation procedures and chemical-specific analyses when the toxicity tests show significant lethality. Where the permittee has identified or suspects specific pollutant and source of effluent toxicity, the permittee shall conduct, concurrent with toxicity testing, chemical-specific analyses for the identified and suspected pollutant and source of effluent toxicity;
  - 3) Quality Assurance Plan The TRE action plan should address record keeping and data evaluation, calibration and standardization, baseline tests, system blanks, controls, duplicates, spikes, toxicity persistence in the samples, randomization, reference toxicant control charts, and mechanisms to detect artifactual toxicity; and
  - 4) Project Organization The TRE Action Plan should describe the project staff, project manager, consulting engineering services (where applicable), consulting analytical and toxicological services, etc.
- c. Within 30 days of submittal of the TRE action plan and schedule, the permittee shall implement the TRE.

- d. The permittee shall submit quarterly TRE activities reports concerning the progress of the TRE. The quarterly TRE activities reports are due on or before April 20th, July 20th, October 20th, and January 20th. The report shall detail information regarding the TRE activities including:
  - 1) results and interpretation of any chemical-specific analyses for the identified and suspected pollutant performed during the quarter;
  - 2) results and interpretation of any characterization, identification, and confirmation tests performed during the quarter;
  - any data and substantiating documentation that identifies the pollutant and source of effluent toxicity;
  - 4) results of any studies/evaluations concerning the treatability of the facility's effluent toxicity;
  - 5) any data that identifies effluent toxicity control mechanisms that will reduce effluent toxicity to the level necessary to eliminate significant lethality; and
  - any changes to the initial TRE plan and schedule that are believed necessary as a result of the TRE findings.
- e. During the TRE, the permittee shall perform, at a minimum, quarterly testing using the more sensitive species. Testing for the less sensitive species shall continue at the frequency specified in Part 1.b.
- f. If the effluent ceases to effect significant lethality, i.e., there is a cessation of lethality, the permittee may end the TRE. A cessation of lethality is defined as no significant lethality for a period of 12 consecutive weeks with at least weekly testing. At the end of the 12 weeks, the permittee shall submit a statement of intent to cease the TRE and may then resume the testing frequency specified in Part 1.b.

This provision accommodates situations where operational errors and upsets, spills, or sampling errors triggered the TRE, in contrast to a situation where a single toxicant or group of toxicants cause lethality. This provision does not apply as a result of corrective actions taken by the permittee. Corrective actions are defined as proactive efforts that eliminate or reduce effluent toxicity. These include, but are not limited to, source reduction or elimination, improved housekeeping, changes in chemical usage, and modifications of influent streams and effluent treatment.

The permittee may only apply this cessation of lethality provision once. If the effluent again demonstrates significant lethality to the same species, the permit will be amended to add a WET limit with a compliance period, if appropriate. However, prior to the effective date of the WET limit, the permittee may apply for a permit amendment removing and replacing the WET limit with an alternate toxicity control measure by identifying and confirming the toxicant and an appropriate control measure.

- g. The permittee shall complete the TRE and submit a final report on the TRE activities no later than 18 months from the last test day of the retest that demonstrates significant lethality. The permittee may petition the Executive Director (in writing) for an extension of the 18-month limit. However, to warrant an extension the permittee must have demonstrated due diligence in its pursuit of the toxicity identification evaluation/TRE and must prove that circumstances beyond its control stalled the toxicity identification evaluation/TRE. The report shall specify the control mechanism that will, when implemented, reduce effluent toxicity as specified in Part 5.h. The report shall also specify a corrective action schedule for implementing the selected control mechanism.
- h. Within 3 years of the last day of the test confirming toxicity, the permittee shall comply with 30 TAC § 307.6(e)(2)(B), which requires greater than 50% survival of the test organism in 100% effluent at the end of 24-hours. The permittee may petition the Executive Director (in writing) for an extension of the 3-year limit. However, to warrant an extension the permittee must have demonstrated due diligence in its pursuit of the toxicity identification evaluation/TRE and must prove that circumstances beyond its control stalled the toxicity identification evaluation/TRE.

The permittee may be exempted from complying with 30 TAC § 307.6(e)(2)(B) upon proving that toxicity is caused by an excess, imbalance, or deficiency of dissolved salts. This exemption excludes instances where individually toxic components (e.g., metals) form a salt compound. Following the exemption, this permit may be amended to include an ion-adjustment protocol, alternate species testing, or single species testing.

- i. Based upon the results of the TRE and proposed corrective actions, this permit may be amended to modify the biomonitoring requirements where necessary, require a compliance schedule for implementation of corrective actions, specify a WET limit, specify a best management practice, and specify a chemical-specific limit.
- j. Copies of any and all required TRE plans and reports shall also be submitted to the U.S. EPA Region 6 office, 6WQ-PO.

# TABLE 2 (SHEET 1 OF 2)

# WATER FLEA SURVIVAL

### GENERAL INFORMATION

|                            | Time | Date |
|----------------------------|------|------|
| Composite Sample Collected |      |      |
| Test Initiated             |      |      |

### PERCENT SURVIVAL

| Time Rep |      | Percent effluent |    |     |     |     |      |  |  |  |
|----------|------|------------------|----|-----|-----|-----|------|--|--|--|
| Time     | Rep  | 0%               | 6% | 13% | 25% | 50% | 100% |  |  |  |
|          | A    |                  |    |     |     |     |      |  |  |  |
|          | В    |                  |    |     |     |     |      |  |  |  |
| o 4h     | С    |                  |    |     |     |     |      |  |  |  |
| 24h      | D    |                  |    |     |     |     |      |  |  |  |
|          | E    |                  |    |     |     |     |      |  |  |  |
|          | MEAN |                  |    |     |     |     |      |  |  |  |

| Enter i | percent | effluent | corresi | onding    | to the  | e LC50  | below: |
|---------|---------|----------|---------|-----------|---------|---------|--------|
|         |         | CILLUCIA | COLLCD  | JULIULLIS | to this | - HO.10 | DCIOW. |

24-hour LC50 = \_\_\_\_\_% effluent

# TABLE 2 (SHEET 2 OF 2)

# FATHEAD MINNOW SURVIVAL

# GENERAL INFORMATION

|                            | Time | Date |
|----------------------------|------|------|
| Composite Sample Collected |      |      |
| Test Initiated             |      |      |

### PERCENT SURVIVAL

| Time R | Don  |    | Percent effluent |     |     |     |      |  |  |
|--------|------|----|------------------|-----|-----|-----|------|--|--|
| Time   | Rep  | 0% | 6%               | 13% | 25% | 50% | 100% |  |  |
|        | A    |    |                  |     |     |     |      |  |  |
|        | В    |    |                  |     |     |     |      |  |  |
| o 4h   | С    |    |                  |     |     |     |      |  |  |
| 24h    | D    |    |                  |     |     |     |      |  |  |
|        | E    |    |                  |     |     |     |      |  |  |
|        | MEAN | _  |                  |     |     |     |      |  |  |

| Enter percent effluent corresponding to the LC50 be | below | C50 | the LC | to | ponding | corres | effluent | percent | Enter |
|---|-------|-----|--------|----|---------|--------|----------|---------|-------|
|---|-------|-----|--------|----|---------|--------|----------|---------|-------|

24-hour LC50 = \_\_\_\_\_% effluent